

Comment from a drainage engineer submitted by planning agent:

*We are only raising existing levels and so there is no change to how the area drains which relies upon percolation into the ground. In any event, the drainage potential will be enhanced because dependent upon the material we use to raise the levels we could use a granular material which has limited fines such that there is say 30% voids ratio*