

BURY COUNCIL
DEPARTMENT FOR OPERATIONS

REF NO: 21/383

FROM: Head of Engineering

TO: Head of Development Management

Planning Application No: 67614

Location: Rapallo Ristorante, High Street, Walshaw, Bury, BL8 3AG

Development: Single storey side extension

RECOMMENDATION

I recommend that this planning application be refused

Reasons

The extension and its surface water drainage arrangements results in an unacceptable impact on the integrity of the adjacent adopted highway due to the unauthorised discharge of surface water onto the adopted footway on High Street, which is detrimental to highway safety and contrary to provisions in the Highways Act 1980.

Comments and Observations

Date: 13 January 2022

Signed:



Head of Engineering

HIGHWAYS ASPECTS ONLY