



Your Reference 68433

Our Reference PR1031590

Contact Gill Hoyle
hoyleg@manchesterfire.gov.uk

Bury Council
Town Hall
Knowsley Street
Bury
Lancashire
BL9 0SW

Chief Fire Officer
Dave Russel, BSc, MIFireE

Greater Manchester Fire and Rescue
Service
146 Bolton Road
Swinton
Manchester
M27 8US

Tel: 0161 736 5866
www.manchesterfire.gov.uk

For the attention of Jennie Townsend

Sent via email - j.l.townsend@bury.gov.uk

14/10/22

Dear Sir/Madam,

Planning Application No:	68433
Address:	BURNT HOUSE FARM TURTON ROAD TOTTINGTON BURY BL8 3QF
Proposal:	Erection of 1 no.detached dwelling to replace existing

The above proposal should meet the requirements for Fire Service access.

The Fire Service requires vehicular access for a fire appliance to within 45m of **all** points within the dwelling.

The access road should be a minimum width of 4.5m and capable of carrying 12.5 tonnes. Additionally if the access road is more than 20m long a turning circle, hammerhead, or other turning point for fire appliances will be required.

There should be a suitable fire hydrant within 165m of the furthest dwelling.

The Fire Service strongly supports the installation of domestic sprinkler systems as a positive measure to protect persons. At a small cost occupants'

can be given the reassurance of a high level of protection. All developers should positively consider the viability of installing domestic sprinkler systems. The access requirements for a dwelling fitted with an approved sprinkler system can deviate from the required standard detailed above, further consultation will be required.

Yours sincerely

A handwritten signature in black ink, appearing to be a stylized 'A' or 'J' followed by a few dots.

On behalf of the
Greater Manchester Combined Authority