

Hi

EH comments

The noise assessment has identified mitigation measures which need to be incorporated into the development.

- All external windows with glazing specification (overall to include frame) of airborne sound insulation Rw32dB. The windows to be replaced with high quality acoustic double glazing (eg 4,12 or 10mm glass) in a well sealed frame.
- Enhanced background ventilation to the bedroom/dining/living room to preclude the need to open windows for ventilation
- Adequate sound insulation for the facade and ceiling elements of the building
- Acoustic sound insulation according to building regulations between the proposed apartments between floors and between the retail units and apartments

thanks

Rob Hall

Unit Manager, Environmental Health Commercial Team
Bury Council | Public Protection Service
3 Knowsley Place | Duke Street | Bury | BL9 0EJ



Follow us on



Please note that the opinions given are those of this department at this time and are subject to change in light of legal developments. Only the courts can give a definitive interpretation of the law.

Privacy Policy

please visit www.bury.gov.uk/privacy to read our recently updated Privacy Policy which explains how Bury Council uses and shares your personal data to give you the best possible experience across our services.