

This drawing is ©TECH:D Ltd and is not to be copied, reproduced or re-distributed either in whole or in part without the prior permission of the originator. The originator shall have no responsibility for any liability, loss, cost, damage or expense arising from or relating to any use of this document other than for its intended purpose on this project. This drawing shall be read in conjunction with all other relevant drawings, specifications and associated documentation. Any discrepancies, errors or omissions are to be reported to the originator before proceeding with work. This drawing is for Local Authority submission only. The client is to seek approval from the land freeholder and all parties who may have an interest in the land. All materials shall be suitable for their purpose and installed in strict accordance with the manufacturers instructions. All workmanship and materials to comply with Building regulations, British standards, Codes of practice and NHBC requirements where relevant. The contractor is to comply with the CDM regulations. All dimensions are to be checked on site by the contractor prior to proceeding with any work.

NOTES / KEY:



Radiator.



Rainwater pipe. Gu=Gully



soil & vent pipe.

FtC=2760

Floor to ceiling.



Boiler.



Manhole/ inspection chamber.

E


Elec meter+ dist board.

G

Gas meter

F

Fire



Timber floor joists span. If known. sf=solid floor



Architectural Designer

27 Oakham Close, Bury BL8 1XJ
t: 07887876428
ddriver@techdtd.co.uk
www.techdtd.co.uk

client

Mr & Mrs R. Jones, 2 Bridge Field Mews, Bury, BL9 7UB.

project

REAR SINGLE STOREY EXTENSION AND TERRACE

status

Planning & Building regulations

drawing

PROPOSED GA SECTION.

L.A.

Bury MBC

date

JULY 22

drawn by

DD.

scale

1:20 @ A3

dwg no

22-06-01 05 rev .

TECH:D LTD

Stone copings to match main house stonework.

Roof lantern size and type to clients choice.
Kerb and installation details to suit lantern and all to manufacturers / suppliers instructions.

Bifold doors to clients choice.

Aco slot drain at doors. Connect to drainage.
Under slung to floor structure is required.

Stone hardstanding to clients choice.
On beam/block floor to contractors/suppliers design/calculations.
Storage space and access under to clients requirements. Weak mix over site concrete to floor void.

Masonry support walls as required to structural floor requirements.
Design/calculations by suppliers.

2340

EXTENSION

Screed/insulation on beam and block floor as described..

Air bricks at 2m ctrs to all perimeter walls to give ventilation below all floors/terraces.

PROPOSED GA A-A SECTION 1:20

