

The submitted information provides an outline drainage strategy, including proposed attenuation measures, indicative discharge rates and consideration of the drainage hierarchy. Nonetheless, United Utilities have advised that the current drainage proposals are not yet acceptable and that further justification is still required in respect of the proposed surface water discharge arrangements, particularly regarding the proposed discharge destination and the consideration of alternative drainage options.

Accordingly, confirmation of the final agreed surface water discharge arrangements, including the agreed point of discharge, discharge rate and supporting justification for the proposed drainage hierarchy, should be secured prior to commencement of development.

Project Engineer (Drainage)