



200 Lichfield Lane
Mansfield
Nottinghamshire
NG18 4RG

T: 01623 637 119 (Planning Enquiries)

E: planningconsultation@coal.gov.uk

W: www.gov.uk/coalauthority

For the attention of: Helen Pressley – Case Officer
Bury Metropolitan Borough Council

[By email: development.control@bury.gov.uk]

13 March 2025

Dear Ms Pressley

Re: Planning application 71473

Erection of building comprising of 7 no. apartments with associated parking and landscaping at Land Between, 208-211 Bury Old Road, Prestwich, Manchester, M25 1JF

Thank you for your notification of 3 March 2025 seeking the views of the Coal Authority on the above.

The Coal Authority is a non-departmental public body sponsored by the Department for Energy Security and Net Zero. As a statutory consultee, the Coal Authority has a duty to respond to planning applications and development plans in order to protect the public and the environment in mining areas.

The Coal Authority response: **Material Consideration**

The application site falls partly within the defined Development High Risk Area due to the presence within the site of an outcropping coal seam. However, whilst the outcropping coal seam is likely to be present at shallow depth beneath rockhead, rockhead itself is anticipated to lie beneath a significant depth of drift/superficial deposits (>30m). Given the significant depth of any coal seam beneath the site we do not consider that a Coal Mining Risk Assessment is required for this proposal and we **DO NOT OBJECT** to this application.

However, should planning permission be granted, we recommend that the following wording is included as an Informative Note on any planning permission granted:

The proposed development lies within an area that has been defined by the Mining Remediation Authority as containing coal mining features at surface or shallow depth. These features may include: mine entries (shafts and adits); shallow coal workings; geological features (fissures and break lines); mine gas and former surface mining sites. Although such features are seldom readily visible, they can often be present and problems can occur, particularly as a result of new development taking place.

Any intrusive activities which disturb or enter any coal seams, coal mine workings or coal mine entries (shafts and adits) requires a Mining Remediation Authority Permit. Such activities could include site investigation boreholes, excavations for foundations, piling activities, other ground works and any subsequent treatment of coal mine workings and coal mine entries for ground stability purposes. Application forms for Mining Remediation Authority permission and further guidance can be obtained from The Mining Remediation Authority's website at: www.gov.uk/get-a-permit-to-deal-with-a-coal-mine-on-your-property

What is a permit and how to get one? –

<https://www.gov.uk/government/publications/permit-process/permit-process>

In areas where shallow coal seams are present caution should be taken when carrying out any on site burning or heat focused activities.

If any future development has the potential to encounter coal seams which require excavating, for example excavation of building foundations, service trenches, development platforms, earthworks, non-coal mineral operations, an Incidental Coal Agreement will be required. Further information regarding Incidental Coal Agreements can be found here -

<https://www.gov.uk/government/publications/incidental-coal-agreement/guidance-notes-for-applicants-for-incidental-coal-agreements>

If any coal mining features are unexpectedly encountered during development, this should be reported immediately to the Mining Remediation Authority on 0800 288 4242. Further information is available on the Mining Remediation Authority website at: <https://www.gov.uk/government/organisations/mining-remediation-authority>.

Please do not hesitate to contact me if you would like to discuss this matter further.

Yours sincerely

Bradley Shelton

Bradley Shelton

Apprentice Town Planner

Disclaimer

The above consultation response is provided by The Coal Authority as a Statutory Consultee and is based upon the latest available data on the date of the response, and electronic consultation records held by The Coal Authority since 1 April 2013. The comments made are also based upon only the information provided to The Coal Authority by the Local Planning Authority and/or has been published on the Council's website for consultation purposes in relation to this specific planning application. The views and conclusions contained in this response may be subject to review and amendment by The Coal Authority if additional or new data/information (such as a revised Coal Mining Risk Assessment) is provided by the Local Planning Authority or the Applicant for consultation purposes.