

From: Gabrielli, Luca

Sent: Monday, February 12, 2024 12:14 PM

To: Clapworthy, Dean <D.Clapworthy@bury.gov.uk>

Subject: Ferngrove House, Rochdale Old Road, Bury, BL9 7LS Application No. 70368

Hello Dean,

I went out to the above address to have a look at the surrounding area and Infront and behind Ferngrove are residential properties.

When the lights are being installed I would put in place some conditions.

- The lights are not pointing in the direction of any nearby properties.
- The lights should only be pointing down to the space that needs to be lit and if possible are sensors.
- Lights being installed should have hoods on them to help prevent light pollution.

This would help reduce the possibility of light pollution affecting those nearby properties.

Many Thanks,

Luca Gabrielli
Environmental Health Officer
Bury Council