

CONTAMINATED LAND – No Comments.

AIR QUALITY – CONDITION

The site is not located within an Air Quality Management Area. The proposed development comprises a garage and EV charging points are proposed. Bury Council has been identified by DEFRA as an area requiring to significantly improve air quality. To support the principles of the Greater Manchester Clean Air Plan in reducing levels of nitrogen dioxide and in order to manage current and future levels of air pollution Bury Council is encouraging the use of cleaner vehicles and welcomes the proposed inclusion of EV charging points. As such and in line the requirements of the Building Regulations (The Building Regulations 2010, [Approved Document S, Infrastructure for the charging of electric vehicles](#)), this Section recommends the following condition to be placed on any grant of permission:

AQ01 - ELECTRIC VEHICLE CHARGE POINTS

- 1 no. electric vehicle (EV) charging point (minimum 7kW*) per parking space.

Certification and photographic evidence of the installation of the agreed electric vehicle charge points shall be submitted to Local Planning Authority for approval prior to the development being brought into use. The infrastructure shall be maintained and operational in perpetuity.

*Mode 3, 7kW (32A) single phase, or 22kW (32A) three phase, and for 50kW Mode 4 rapid charging may be required. British Standard BS EN 61851-1:2019 to be used. Further information regarding minimum standards can be found at <https://www.gov.uk/transport/low-emission-and-electric-vehicles>.

Reason: To encourage the uptake of ultra-low emission vehicles and ensure the development is sustainable and to safeguard residential amenity, public health and quality of life with respect to Local Air Quality, in accordance with paragraphs 112e, 117e, 187e and 199 of the National Planning Policy Framework (December 2024) and Places for Everyone Policy JP-S5 (Clean Air).

Furthermore, it looks like the property has a new or shared [private water supply](#). Please see here for information on [registering](#) the private water supply and here for [single dwelling supplies](#).

Environmental Protection

24/06/25

envsection@bury.gov.uk