

Luminaire Schedule						
Symbol	Qty	Label	Arrangement	Description	Lum. Lumens	LLF
	2	EX1	SINGLE	120w LED 4000k Viva City Flood 780mA with FW70 Optic column mounted at 6m.	13970	0.900
	8	EX1W	SINGLE	120w LED 4000k Viva City Flood 780mA with FW70 Optic building mounted at 6m.	13970	0.900
	2	EX2	SINGLE	76w LED 4000k (4 module) 700mA Italo 1 with S05 Optic column mounted at 6m.	8990	0.900
	4	EX3	SINGLE	24w 4000k 1540mm (5ft) Climate Extra Single LED Array (Standard) mounted under canopy at 5.4m.	3401	0.900
	4	EX4E	SINGLE	6w LED 4000k Semita Urban Emergency bulkhead with cycle optic building mounted at 3m.	819	0.900
	2	EX5	SINGLE	Atlas LED Bulkhead. 2,100 lum.lm, 21W, 100lm/W, 4000K, Standard Driver, IP65, IK08, 1.3kg.	2100	0.900

THIS DRAWING IS INDICATIVE AND REPRESENTS ONLY THE DESIGN INTENT, THE CONTRACTOR MUST PRODUCE FULLY CO-ORDINATED WORKING / INSTALLATION DRAWINGS AS REFERRED TO IN THE CONTRACT DOCUMENTATION



REV	DESCRIPTION	CH	NS	KM	03/23
BY	CHK	APP	DATE		

Project Status: INFORMATION



The Multi-disciplinary Engineering Consultancy

Core, Workfile
Brown Street
Manchester, M2 1DH
E: mano@harleyhaddow.com
Edinburgh | Glasgow | London | Manchester
harleyhaddow.com
Association for Consulting and Engineering (ACE)

Project: 310498
WHITEFIELD FIRE STATION

Drawing Title:
PROPOSED EXTERNAL
LIGHTING LAYOUT

Scale @ A1 1:200	Date MAR 2023	Engineer NS
Drawing No. 310498-HAH-XX-00-D-E-09610	Revision P01	