

From: Hall, Rob A <bury.gov.uk>

Sent: 19 June 2025 13:23

To: Development Control <bury.gov.uk>

Subject: Re: 71874: Consultation on Planning Application

The noise assessment has concluded no affects from the 2 extract flues using Fan MUB/T 062 560 with silencer acoustic R02 -4 -1500 (Mel). This should be used for the development,

regards

A handwritten signature in black ink, appearing to read 'Rob Hall', with a stylized, cursive script.

Rob Hall

Unit Manager, Commercial Team

Bury Council | Department for Operations | Public Protection

3 Knowsley Place | Duke Street | Bury | BL9 0EJ