




**RADON RISK HAS
CHANGED
FURTHER ACTION IS
REQUIRED.**

NOTES: DO NOT SCALE
Records reviewed as part of the Gas Addendum Letter for the site (by GRM ref. GRM/P10147/GAL.1 dated 19th January 2023) stated that the site is not in an area where radon protective measures are required.

The updated radon maps suggest that radon protective measures may be required, therefore a site specific BGS radon report is recommended.

CLIENT:
**Day Project Management
Limited**

PROJECT:
Updated Radon Areas

TITLE:
**Emergency Department,
Fairfield General Hospital, Bury,
Greater Manchester**

SCALE@SIZE :	ISSUE:
NTS	Final
DESIGN/DRAWN :	DATE:
DES	March 2023
ENQUIRY No:	DRAWING No:
P10147	001
© GRM Development Solutions Ltd	
© Crown Copyright. AL 100014100	

GRM

GRM Development Solutions Ltd
Laurus House, Centrum 100
Burton-on-Trent, Staffs, DE14 2WH
Tel: 01283 551249
info@grm-uk.com www.grm-uk.com