

Hi

Please put condition HOT5 on from EH

Cooking Fumes (the 'HOT5')

No development shall commence unless and until a scheme for treating, diluting and dispersing fumes and odours has been submitted to and approved in writing by the Local Planning Authority. The scheme submitted shall include a written statement from a suitably qualified person who is a member of the Heating and Ventilation Contractors Association (HVCA) or an equivalent professional body, stating that the fume treatment to be installed complies with or exceeds the 'Minimum Requirements For Odour Control' provided by the Guidance on the Control of Odour and Noise from Commercial Kitchen Exhaust Systems :DEFRA 2005 (or if applicable such superseding guidance as shall prevail at the time of commencement of the development).

The scheme to be submitted shall also include the relevant manufacturer and installer instructions for any associated equipment with details of maintenance requirements.

The scheme as approved shall be implemented, available for use and maintained in accordance with the approved scheme whilst it shall serve the development.

Reason. To protect the residential amenities of nearby residential property from impact upon from fumes and odour pursuant to UDP Policy S2/6 - Food and Drink.

Noise not to increase ambient noise

Noise from or associated with the proposed activity/development hereby permitted shall not increase the prevailing ambient noise levels as measured at the boundary of the site.

The ambient noise levels shall be determined by survey, by the applicant, to the satisfaction of the Local Planning Authority (LPA) and a copy of the survey report shall be provided to the LPA before any development takes place.

thanks

thanks

Unit Manager, Commercial Team
Bury Council | Department for Operations | Public Protection
3 Knowsley Place | Duke Street | Bury | BL9 0EJ