

68279 – Greystones, Redisher Lane, Ramsbottom

Demolition of existing outbuilding; Single storey rear extension; Porch with canopy at rear; New window opening/replacement windows to corridor to east elevation; New french door opening (dining room) to west elevation

No objection.

It is recommended a condition is added to secure satisfactory external finishes:

External stone finishes of the development hereby approved shall match the external stone finishes of the existing dwellinghouse. They shall match the stone size, colour, course and external face texture as those in the external elevations of the existing dwellinghouse.

Mark Kilby PGDip (Building Conservation & Adaptation)

Conservation officer

13/5/22