

Revised Air Quality response

Having considered Approved Document S, seems that for all non-residential buildings (with more than 10 spaces), we're looking at a condition for:

- Electric vehicle (EV) charging points (minimum 7kW*) for a minimum of 10% of the proposed parking spaces and ducting to be installed in 20% of the proposed parking spaces.