

NOTICE OF PLANNING PERMISSION

Town and Country Planning Act 1990 Town and Country Planning (Development Management Procedure) (England) Order 2015

To:

Mr Dearden
PPY design Ltd
2 Helmsore Road
Holcombe Village
Bury
BL8 4PA

On Behalf Of:

Mr Kingston
Monk House
Parkside Road
Winwick
Warrington
WA2 8ST

PART 1 - Particulars of Application

Application Number: 67687

Date of Registration: 20/10/2021

Proposal:

Erection of 100 seater football stand following removal of existing stand.

Location:

Prestwich Hey F C, Sandgate Road,
Whitefield, M45 6NT

PART 2 - Particulars of Decision

Bury Metropolitan Borough Council hereby give notice in pursuance of the provisions of the Town and Country Planning Act 1990 that permission has been **GRANTED** for the carrying out of the development referred to in Part 1 hereof in accordance with the application and plans submitted subject to the following conditions:-

- 1 The development must be begun not later than three years beginning with the date of this permission.
Reason. Required to be imposed by Section 91 Town & Country Planning Act 1990.
- 2 This decision relates to drawings - Location plan NK1-00; Existing site layout NK1-01; Proposed site layout NK1-02; Proposed stand NK1-03 and the development shall not be carried out except in accordance with the drawings hereby approved.
Reason. For the avoidance of doubt and to ensure a satisfactory standard of design pursuant to the policies of the Bury Unitary Development Plan listed.
- 3 Prior to the erection of the football stand hereby approved, the existing football stand shall be permanently removed from site.
Reason. To ensure the suitable phasing of the development and maintain acceptable levels of amenity and facilities for the surrounding area pursuant to Bury Unitary Development Plan Policies RT3/4 - Noisy Sports, EN1/2 - Townscape and Built Design and HT2/4 - Car Parking and New Development.

Statement in accordance with Article 35(2) Town and Country Planning (Development Management Procedure) (England) (Amendment) Order 2015

The proposal complies with the development plan and would improve the economic, social and environmental conditions of the area. It therefore comprises sustainable development and the Local Planning Authority worked proactively and positively to issue the decision without delay. The Local Planning Authority has therefore implemented the requirement in Paragraph 38 of the National Planning Policy Framework.

The following policies of the Bury Unitary Development Plan, National and Regional Government were considered relevant:

NPPF	National Planning Policy Framework
EN1/2	EN1/2 - Townscape and Built Design
RT1/1	RT1/1 - Protection of Recreation Provision in the Urban Area
RT1/2	RT1/2 - Improvement of Recreation Facilities
RT3/5	RT3/5 - Noisy Sport
HT2/4	HT2/4 - Car Parking and New Development
HT6/2	HT6/2 - Pedestrian/Vehicular Conflict
SPD11	Development Control Policy Guidance Note 11 - Parking Standards in Bury

This decision relates only to the Town and Country Planning Acts and does not include any consent or approval under any other enactment or under the Building Regulations. Any other consent or approval which is necessary must be obtained from the appropriate authority.

Applicant Plan Numbers:

Location plan NK1-00; Existing site layout NK1-01; Proposed site layout NK1-02; Proposed stand NK1-03

NOTES TO APPLICANT

. United Utilities advisory

In accordance with the National Planning Policy Framework (NPPF) and the National Planning Practice Guidance (NPPG), the site should be drained on a separate system with foul water draining to the public sewer and surface water draining in the most sustainable way.

The NPPG clearly outlines the hierarchy to be investigated by the developer when considering a surface water drainage strategy. We would ask the developer to consider the following drainage options in the following order of priority:

1. into the ground (infiltration);
2. to a surface water body;
3. to a surface water sewer, highway drain, or another drainage system;
4. to a combined sewer.

We recommend the applicant implements the scheme in accordance with the surface water drainage hierarchy outlined above.

If the applicant intends to offer wastewater assets forward for adoption by United Utilities, the proposed detailed design will be subject to a technical appraisal by an Adoptions Engineer as we need to be sure that the proposal meets the requirements of Sewers for adoption and United Utilities' Asset Standards. The proposed design should give consideration to long term operability and give United Utilities a cost effective proposal for the life of the assets. Therefore, should this application be approved and the applicant wishes to progress a Section 104 agreement, we strongly recommend that no construction commences until the detailed drainage design, submitted as part of the Section 104 agreement, has been assessed and accepted in writing by United Utilities. Any works carried out prior to the technical assessment

being approved is done entirely at the developers own risk and could be subject to change.

Details of both our S106 sewer connections and S104 sewer adoptions processes (including application forms) can be found on our website

<http://www.unitedutilities.com/builders-developers.aspx>

Please note we are not responsible for advising on rates of discharge to the local watercourse system. This is a matter for you to discuss with the Lead Local Flood Authority and / or the Environment Agency if the watercourse is classified as main river.

Water supply

If the applicant intends to obtain a water supply from United Utilities for the proposed development, we strongly recommend they engage with us at the earliest opportunity. If reinforcement of the water network is required to meet the demand, this could be a significant project which should be accounted for in the project timeline for design and construction.

To discuss a potential water supply or any of the water comments detailed above, the applicant can contact the team at DeveloperServicesWater@uuplc.co.uk.

Please note, all internal pipework must comply with current Water Supply (water fittings) Regulations 1999.

United Utilities' property, assets and infrastructure

Where United Utilities' assets exist, the level of cover to the water mains and public sewers must not be compromised either during or after construction.

For advice regarding protection of United Utilities' assets, the applicant should contact the teams as follows:

Water assets – DeveloperServicesWater@uuplc.co.uk

Wastewater assets – WastewaterDeveloperServices@uuplc.co.uk

It is the applicant's responsibility to investigate the possibility of any United Utilities' assets potentially impacted by their proposals and to demonstrate the exact relationship between any United Utilities' assets and the proposed development.

A number of providers offer a paid for mapping service including United Utilities. To find out how to purchase a sewer and water plan from United Utilities, please visit the Property Searches website; <https://www.unitedutilities.com/property-searches/>. You can also view the plans for free. To make an appointment to view our sewer records at your local authority please contact them direct, alternatively if you wish to view the water and the sewer records at our Lingley Mere offices based in Warrington please ring 0370 751 0101 to book an appointment.

Due to the public sewer transfer in 2011, not all sewers are currently shown on the statutory sewer records and we do not always show private pipes on our plans. If a sewer is discovered during construction; please contact a Building Control Body to discuss the matter further.

For any further information regarding Developer Services and Planning, please visit our website at <http://www.unitedutilities.com/builders-developers.aspx>

Signed:

A handwritten signature in black ink, appearing to read "Joe Kahan", is positioned in the upper left area of the page.

4 of 4

.....
On behalf of the Council

Date of Decision: 07/01/2022