

65949 – 1C Smithy Street

Physical Security

- Any new external fittings (i.e. shutters, windows or doors) should be certified to Secured by Design standards.
- Any new glazing in external doors, ground floor or easily accessible windows should include at least one pane of laminated glass rated as P4A under EN 356.
- A CCTV system should be included within these licensed premises and should be capable of monitoring the following areas: external doorways, all internal spaces.
- Signage should be displayed to indicate the areas of the premises that are restricted to staff only.
- Any staff areas that are to be included within the proposal should be access controlled and restricted to members of staff only.
- Dusk till dawn lighting should be installed above all external doors.