

## **ENGINEERING CONSULTANCY SERVICES**

### **DRAINAGE CONSULTATION**

**Date: 18/03/25**

**Your Ref:** 71278

**Location:** 12 Owlerbarrow Road, Bury, BL8 1RD

**Proposal:** Erection of 1 no. dwelling at rear

### **RECOMMENDATIONS**

No objections to the proposed development subject to the following:

**CONDITION:** Development shall not commence until details of surface water drainage proposals have been submitted to and approved by the Local Planning Authority. The scheme must be based on the hierarchy of drainage options in the National Planning Practice Guidance and be designed in accordance with the Non-Statutory Technical Standards for Sustainable Drainage Systems (March 2015). This must include assessment of potential SuDS options for surface water drainage with appropriate calculations and test results to support the chosen solution. Details of proposed maintenance arrangements should also be provided

**REASON:** To promote sustainable development. The current application contains insufficient information regarding the proposed drainage scheme to fully assess the impact.

### **Informative Notes for the Applicant**

|      |                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                        |
|------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| N039 | The site is to be drained on a separate system of drainage with surface water and foul sewage being combined at the last manhole before connection to public sewer                                                                                                                                                                                                                                                                                                                                                                                                                                     |
| N040 | Surface water discharge to be limited to existing flow from site less a minimum 40% reduction in run-off to allow for climate change to prevent surcharge of public sewerage system downstream of the proposed development Chapter 10 of the National Planning Policy Framework - Meeting the Challenge of Climate Change, Flooding and Coastal Change and Unitary Development Plan Policy EN5/1 - New Development and Flood Risk and its associated SPD 16 Design and Layout of New Development in Bury. Climate change allowance should be increased to 70% for sites which fall within Flood Zone 3 |
| N041 | Application forms for permission to connect to the public sewer should be obtained by telephoning United Utilities PLC on 08456 020406 or online at <a href="http://www.unitedutilities.com">www.unitedutilities.com</a>                                                                                                                                                                                                                                                                                                                                                                               |



**Andy Southgate**  
**Principal Engineer [Structures & Drainage]**  
**Engineering Consultancy Services**