

Bury Metropolitan Borough Council

Our ref: SO/2025/124668/03-L01
Your ref: 71426

Sent via email

Date: 7 November 2025

Dear Planning Team

Demolition of buildings and erection of 87 no. Affordable dwellings and associated access off dumers lane, landscaping and parking.

Land adjacent to Bealey Industrial Estate, Dumers Lane, Radcliffe, Manchester, M26 2BD

Thank you for consulting us on the above.

Environment Agency position

We have no objection to this proposal subject to the following conditions being included in any permission granted.

Flood Risk

The proposed development will only meet the National Planning Policy Framework's requirements in relation to flood risk if the following planning condition is included.

Condition 1: The development shall be carried out in accordance with the submitted flood risk assessment (Response to Environment Agency/ 27th October 2025) and the following mitigation measures it details:

- Finished floor levels shall be set no lower than 68.50 metres above Ordnance Datum (AOD)

These mitigation measures shall be fully implemented prior to occupation and subsequently in accordance with the scheme's timing/phasing arrangements. The measures detailed above shall be retained and maintained thereafter throughout the lifetime of the development.

Reason: To reduce the risk of flooding to the proposed development and future occupants.

Ground water and Contaminated Land

We have reviewed the Site Investigation Report for Land Adjacent to Bealey Industrial Estate, Radcliffe by Coopers Ltd dated November 2024.

We have identified that the land has been used in association with industrial processes in the immediate vicinity. This land use is likely to have led to elevated concentrations of contamination being introduced to the land which could pose a risk to the Controlled waters.

We have identified that the water environment is sensitive in this area being immediately above Secondary Aquifers (associated with the superficial and bedrock deposits) and is in close proximity to known surface watercourse.

This submission has identified the adjacent previous land use to be associated with the paper industry and that previous areas of the site have been subject to waste disposal operations.

We advise the applicant that further consideration needs to be applied to future sampling suites in that we recommend that analysis for Per- and Polyfluoroalkyl substances (PFAS) is added to the range of contaminants which are tested for (known to be associated with former paper industries) and that consideration is given to the potential reuse and retention of materials which the Environment Agency may consider to be waste.

The applicant's submissions demonstrate that it will be possible to manage the risks posed to controlled waters by this development. Further detailed information will however be required before built development is undertaken. We believe that it would place an unreasonable burden on the developer to ask for more detailed information prior to the granting of planning permission but respect that this is a decision for the local planning authority.

In light of the above, the proposed development will be acceptable if a planning condition is included requiring the submission of a remediation strategy. This should be carried out by a competent person in line with paragraph 196 of the National Planning Policy Framework.

Without these conditions we would object to the proposal in line with paragraph 187 of the National Planning Policy Framework because it cannot be guaranteed that the development will not be put at unacceptable risk from, or be adversely affected by, unacceptable levels of water pollution.

Condition 2: No development approved by this planning permission shall commence until a remediation strategy to deal with the risks associated with contamination of the site in respect of the development hereby permitted, has been submitted to, and approved in writing by, the local planning authority. This strategy will include the following components:

1. Additional, appropriate, site investigation scheme, based on the information already submitted, to provide information for a detailed assessment of the risk to all receptors that may be affected, including those off-site.
2. The results of the site investigation and the detailed risk assessment referred to in (1) and, based on these, an options appraisal and remediation strategy giving full details of the remediation measures required and how they are to be undertaken.
3. A verification plan providing details of the data that will be collected in order to demonstrate that the works set out in the remediation strategy in (2) are complete and identifying any requirements for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action.

Any changes to these components require the written consent of the local planning authority. The scheme shall be implemented as approved.

Reason: To ensure that the development does not contribute to, and is not put at unacceptable risk from or adversely affected by, unacceptable levels of water pollution in line with paragraph 187 of the National Planning Policy Framework.

Condition 3: No drainage systems for the infiltration of surface water to the ground are permitted where adverse concentrations of contamination and known or suspected to be present other than with the written consent of the local planning authority. Any proposals for such systems must be supported by an assessment of the risks to controlled waters. The development shall be carried out in accordance with the approved details.

Reason: To ensure that the development does not contribute to, and is not put at unacceptable risk from or adversely affected by, unacceptable levels of water pollution in line with paragraph 187 of the National Planning Policy Framework.

Condition 4: Piling or any other foundation designs using penetrative methods shall not be permitted other than with the express written consent of the local planning authority, which may be given for those parts of the site where it has been demonstrated that there is no resultant unacceptable risk to groundwater. The development shall be carried out in accordance with the approved details.

Reason: To ensure that the proposed piling, does not harm groundwater resources in line with paragraph 187 of the National Planning Policy Framework and Position Statement J of the [‘The Environment Agency’s approach to groundwater protection’](#).

Condition 5: Prior to any part of the permitted development being occupied, a verification report demonstrating the completion of works set out in the approved remediation strategy and the effectiveness of the remediation shall be submitted to, and approved in writing, by the local planning authority. The report shall include results of sampling and monitoring carried out in accordance with the approved verification plan to demonstrate that the site remediation criteria have been met.

Reason: To ensure that the development does not contribute to, and is not put at unacceptable risk from or adversely affected by, unacceptable levels of water pollution in line with paragraph 187 of the National Planning Policy Framework.

Advice to applicant

Model Procedures and good practice

This development site appears to have been the subject of past industrial activity which may pose a risk of pollution to controlled waters.

We recommend that you should:

- Follow the risk management framework provided in Guidance on Land contamination risk management (LCRM) [Land contamination risk management \(LCRM\) - GOV.UK \(www.gov.uk\)](#), when dealing with land affected by contamination

- Refer to the [contaminated land](#) pages on gov.uk for more information
- Refer to [‘The Environment Agency’s approach to groundwater protection’](#)

All investigations of land potentially affected by contamination should be carried out by or under the direction of a suitably qualified competent person and in accordance with BS 10175 (2001) Code of practice for the investigation of potentially contaminated sites.

Where the remediation / redevelopment of the site will involve waste management issues we offer the following advice:

Waste on-site

The CL:AIRE Definition of Waste: Development Industry Code of Practice (version 2) provides operators with a framework for determining whether or not excavated material arising from site during remediation and/or land development works is waste or has ceased to be waste. Under the Code of Practice:

- excavated materials that are recovered via a treatment operation can be reused on-site providing they are treated to a standard such that they are fit for purpose and unlikely to cause pollution
- treated materials can be transferred between sites as part of a hub and cluster project
- some naturally occurring clean material can be transferred directly between sites

Developers should ensure that all contaminated materials are adequately characterised both chemically and physically, and that the permitting status of any proposed on-site operations are clear. If in doubt, the Environment Agency should be contacted for advice at an early stage to avoid any delays.

We recommend that developers should refer to:

- the [position statement](#) on the Definition of Waste: Development Industry Code of Practice
- The [waste management](#) page on GOV.UK

Waste to be taken off-site

Contaminated soil that is (or must be) disposed of is waste. Therefore, its handling, transport, treatment and disposal are subject to waste management legislation, which includes:

- Duty of Care Regulations 1991
- Hazardous Waste (England and Wales) Regulations 2005
- Environmental Permitting (England and Wales) Regulations 2016
- The Waste (England and Wales) Regulations 2011

Developers should ensure that all contaminated materials are adequately characterised both chemically and physically in line with British Standard BS EN 14899:2005 'Characterization of Waste - Sampling of Waste Materials - Framework for the Preparation and Application of a Sampling Plan' and that the permitting status of any proposed treatment or disposal activity is clear. If in doubt, the Environment Agency should be contacted for advice at an early stage to avoid any delays.

If the total quantity of hazardous waste material produced or taken off-site is 500kg or greater in any 12 month period, the developer will need to register with us as a hazardous waste producer. Refer to the [hazardous waste](#) pages on GOV.UK for more information.

Introduction of SUDS:

Approved Document Part H of the Building Regulations 2000 establishes a hierarchy for surface water disposal, which encourages a SUDS approach. Under Approved Document Part H the first option for surface water disposal should be the use of SUDS, which encourage infiltration such as soakaways or infiltration trenches. In all cases, it should be established that these options are feasible, can be adopted and properly maintained and would not lead to any other environmental problems. For example, using soakaways or other infiltration methods on contaminated land carries groundwater pollution risks and may not work in areas with a high water table. Where the intention is to dispose to soakaway, these should be shown to work through an appropriate assessment carried out under Building Research Establishment (BRE) Digest 365.

Piling and Penetrative ground improvement methods:

Piling or any other foundation designs using penetrative methods can result in risks to potable supplies from, for example, pollution / turbidity, risk of mobilising contamination, drilling through different aquifers and creating preferential pathways. Thus it should be demonstrated that any proposed piling will not result in contamination of groundwater.

Dewatering

Dewatering is the removal/abstraction of water (predominantly, but not confined to, groundwater) in order to locally lower water levels near the excavation. This can allow operations to take place, such as mining, quarrying, building, engineering works or other operations, whether underground or on the surface. Any dewatering activities on-site could have an impact upon local wells, water supplies and/or nearby watercourses and environmental interests. This activity was previously exempt from requiring an abstraction licence. Since 1 January 2018, most cases of new planned dewatering operations above 20 cubic metres a day will require a water abstraction licence from us prior to the commencement of dewatering activities at the site. More information is available on gov.uk:

<https://www.gov.uk/guidance/water-management-apply-for-a-water-abstraction-or-impoundment-licence#apply-for-a-licence-for-a-previously-exempt-abstraction>.

Regulatory position statements

Discharges from dewatering to surface water or groundwater will require an Environmental Permit unless you can meet the conditions of the RPS or exemptions or exclusions for groundwater activities. The following Regulatory Position Statement will apply: 'Temporary dewatering from excavations to surface water.'

<https://www.gov.uk/government/publications/temporary-dewatering-from-excavations-to-surface-water>

Condition wording

If you wish to amend the wording of our requested conditions or if you wish to merge them with other Local Planning Authority conditions, please contact us to discuss the revised wording.

Decision notice

In accordance with the planning practice guidance ([determining a planning application, paragraph 019](#)), please notify us by email within two weeks of a decision being made or application withdrawn. Please provide us with a URL of the decision notice, or an electronic copy of the decision notice or outcome.

Please note that our comments are based on the details available to us at the time of writing. If any subsequent changes are made to the application, please reconsult us.

Should you have any queries regarding this response, please contact me.

Yours faithfully

Miss Jennifer Wilson
Planning Specialist

Direct e-mail SPPlanning.RFH@environment-agency.gov.uk