

BURY COUNCIL
DEPARTMENT FOR OPERATIONS

REF NO: 21/367

FROM: Head of Engineering

TO: Head of Development Management

Planning Application No: 67747

Location: Block A, Clerke Street, Bury, BL9 0PN

Development: Advertisement consent for 3 No. illuminated fascia signs;
3 No. internally illuminated projecting signs

RECOMMENDATION

I recommend that any planning permission given shall include the following condition:

The luminance of the signs shall not exceed 300cd/m² each. (ADL4 Amended)

Reasons

To avoid undue distraction to traffic in the interests of road safety and to protect the amenity of adjoining occupiers.

Comments and Observations

Date: 14 December 2021

Signed:



Head of Engineering

HIGHWAYS ASPECTS ONLY