

Ms. Jennie Townsend
Bury Metropolitan Borough Council
Town Hall
Knowsley Street
Bury
Lancashire
BL9 0SW

Our ref: SO/2024/124397/02-L01
Your ref: 70993
Date: 14 January 2025

Dear Ms. Townsend

****ADDITIONAL INFO RECEIVED** DEMOLITION OF EXISTING CLASS B2/B8 INDUSTRIAL BUILDINGS AND CLASS E(G) OFFICES; RECLADDING AND REFURBISHMENT OF RETAINED CLASS B2/B8 INDUSTRIAL BUILDINGS AND CHANGE OF USE OF RETAINED CLASS E(G) AND SUI GENERIS TO CLASS B2/B8**

WARTH INDUSTRIAL PARK, WARTH ROAD, BURY, BL9 9NB

Thank you for referring additional details to the Environment Agency regarding the above application. The information submitted is satisfactory and meets with our approval. We can therefore remove our previous objection and would like to make the following comments.

Environment Agency position

Flood Risk

The proposed development will only meet the National Planning Policy Framework's requirements in relation to flood risk if the following planning condition is included.

Condition

The development shall be carried out in accordance with the submitted flood risk assessment (FRA241100 - December 2024) and the following mitigation measures it details:

- Including flood resilience measures to ensure a suitable level of protection against potential flood events
- Signing up to the EA Flood Warning Service to receive Flood Warnings for the site
- Providing a suitable Flood Management Plan which takes into consideration a range of potential scenarios

Environment Agency
Richard Fairclough House Knutsford Road, Warrington, WA4 1HT.
Customer services line: 03708 506 506
www.gov.uk/environment-agency

Cont/d..

These mitigation measures shall be fully implemented prior to occupation and subsequently in accordance with the scheme's timing/ phasing arrangements. The measures detailed above shall be retained and maintained thereafter throughout the lifetime of the development.

Reasons

- To reduce the risk of flooding to the proposed development and future occupants
- To ensure the structural integrity of the existing flood defences, thereby reducing the risk of flooding

Environmental permit - advice to applicant

The Environmental Permitting (England and Wales) Regulations 2016 require a permit to be obtained for any activities which will take place:

- on or within 8 metres of a main river (16 metres if tidal)
- on or within 8 metres of a flood defence structure or culverted main river (16 metres if tidal)
- involving quarrying or excavation within 16 metres of any main river, flood defence (including a remote defence) or culvert
- in the floodplain of a main river if the activity could affect flood flow or storage and potential impacts are not controlled by a planning permission

This applies to the planned development for building C and building D as detailed in the FRA. Both buildings are near both the main river and several Environment Agency maintained flood defence assets along the southern boundary of the site.

For further guidance please visit <https://www.gov.uk/guidance/flood-risk-activities-environmental-permits> or contact our National Customer Contact Centre on 03708 506 506. The applicant should not assume that a permit will automatically be forthcoming once planning permission has been granted, and we advise them to consult with us at the earliest opportunity.

Advice to LPA/ applicant

This development has been proposed within an area identified as being at risk of flooding and includes the provision of car parking within buildings. The applicant should be aware that vehicles can start to float in flood depths of less than 60cm – less if it is fast-flowing. The applicant must satisfy themselves that any relevant building will be constructed in such a way that vehicles floating or displaced as a result of flooding, would not jeopardise its structural stability.

In addition, the applicant should ensure that any sensitive infrastructure such as gas and water pipes or electrical cabling are located and designed to withstand the potential impacts of floating or displaced vehicles.

Contaminated Land

We have reviewed the Phase 1 Preliminary Risk Assessment by LK Group dated July 2024 for the proposed re-development of the current Warth Business Park, Radcliffe.

The previous use of the proposed development site for historical industrial purposes presents a high to medium risk of contamination that could be mobilised during construction to pollute controlled waters. Controlled waters are particularly sensitive in this location because the proposed development site is located upon a Secondary A aquifer and immediately adjacent to the River Irwell.

On this occasion, the applicant's submissions demonstrate that it should be possible to manage the risks posed to controlled waters by this development.

Further detailed information will however be required before built development is undertaken. We believe that it would place an unreasonable burden on the developer to ask for more detailed information prior to the granting of planning permission but respect that this is a decision for the local planning authority.

Considering the above, the proposed development will be acceptable if a planning condition is included requiring the submission of a remediation strategy. This should be carried out by a competent person in line with paragraph 183 of the National Planning Policy Framework.

Without these conditions we would object to the proposal in line with paragraph 180 of the National Planning Policy Framework because it cannot be guaranteed that the development will not be put at unacceptable risk from, or be adversely affected by, unacceptable levels of water pollution.

Condition

No development approved by this planning permission shall commence until a remediation strategy to deal with the risks associated with contamination of the site in respect of the development hereby permitted, has been submitted to, and approved in writing by, the local planning authority. This strategy will include the following components:

1. A site investigation scheme, based on the submission of a phase 1 preliminary risk assessment, to provide information for a detailed assessment of the risk to all receptors that may be affected, including those off-site.
2. The results of the site investigation and the detailed risk assessment referred to in (1) and, based on these, an options appraisal and remediation strategy giving full details of the remediation measures required and how they are to be undertaken.
3. A verification plan providing details of the data that will be collected to demonstrate that the works set out in the remediation strategy in (2) are complete and identifying any requirements for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action.

Any changes to these components require the written consent of the local planning authority. The scheme shall be implemented as approved.

Reason

To ensure that the development does not contribute to and is not put at unacceptable risk from or adversely affected by unacceptable levels of water pollution in line with paragraph 180 of the National Planning Policy Framework.

Condition

Piling or any other foundation designs using penetrative methods shall not be permitted other than with the express written consent of the local planning authority, which may be given for those parts of the site where it has been demonstrated that there is no resultant unacceptable risk to groundwater. The development shall be carried out in accordance with the approved details.

Reason

To ensure that the proposed piling, does not harm groundwater resources in line with paragraph 180 of the National Planning Policy Framework and Position Statement J of the [‘The Environment Agency’s approach to groundwater protection’](#).

Condition

Prior to any part of the permitted development being brought into use, a verification report demonstrating the completion of works set out in the approved remediation strategy and the effectiveness of the remediation shall be submitted to, and approved in writing, by the local planning authority. The report shall include results of sampling and monitoring carried out in accordance with the approved verification plan to demonstrate that the site remediation criteria have been met.

Reason

To ensure that the development does not contribute to and is not put at unacceptable risk from or adversely affected by unacceptable levels of water pollution in line with paragraph 180 of the National Planning Policy Framework.

Advice to applicant

Model Procedures and good practice

This development site appears to have been the subject of past industrial activity which may pose a risk of pollution to controlled waters.

We recommend that you should:

- Follow the risk management framework provided in Guidance on Land contamination risk management (LCRM) [Land contamination risk management \(LCRM\) - GOV.UK \(www.gov.uk\)](#), when dealing with land affected by contamination
- Refer to our [Guiding principles for land contamination](#) for the type of information that we require in order to assess risks to controlled waters from the site - the local authority can advise on risk to other receptors, such as human health
- Refer to the [contaminated land](#) pages on gov.uk for more information
- Refer to [‘The Environment Agency’s approach to groundwater protection’](#)

All investigations of land potentially affected by contamination should be carried out by or under the direction of a suitably qualified competent person and in accordance with BS 10175 (2001) Code of practice for the investigation of potentially contaminated sites. Where the remediation / redevelopment of the site will involve waste management issues we offer the following advice:

Waste on-site

The CL:AIRE Definition of Waste: Development Industry Code of Practice (version 2) provides operators with a framework for determining whether excavated material arising from site during remediation and/or land development works is waste or has ceased to be waste. Under the Code of Practice:

- excavated materials that are recovered via a treatment operation can be reused on-site providing they are treated to a standard such that they are fit for purpose and unlikely to cause pollution
- treated materials can be transferred between sites as part of a hub and cluster project
- some naturally occurring clean material can be transferred directly between sites

Developers should ensure that all contaminated materials are adequately characterised both chemically and physically, and that the permitting status of any proposed on-site operations is clear. If in doubt, the Environment Agency should be contacted for advice at an early stage to avoid any delays.

We recommend that developers should refer to:

- the [position statement](#) on the Definition of Waste: Development Industry Code of Practice
- The [waste management](#) page on GOV.UK

Waste to be taken off-site

Contaminated soil that is (or must be) disposed of is waste. Therefore, its handling, transport, treatment and disposal are subject to waste management legislation, which includes:

- Duty of Care Regulations 1991
- Hazardous Waste (England and Wales) Regulations 2005
- Environmental Permitting (England and Wales) Regulations 2016
- The Waste (England and Wales) Regulations 2011

Developers should ensure that all contaminated materials are adequately characterised both chemically and physically in line with British Standard BS EN 14899:2005 'Characterization of Waste - Sampling of Waste Materials - Framework for the Preparation and Application of a Sampling Plan' and that the permitting status of any proposed treatment or disposal activity is clear. If in doubt, the Environment Agency should be contacted for advice at an early stage to avoid any delays.

If the total quantity of hazardous waste material produced or taken off-site is 500kg or greater in any 12-month period, the developer will need to register with us as a hazardous waste producer. Refer to the [hazardous waste](#) pages on GOV.UK for more information.

Piling and Penetrative ground improvement methods:

Piling or any other foundation designs using penetrative methods can result in risks to potable supplies from, for example, pollution / turbidity, risk of mobilising contamination, drilling through different aquifers and creating preferential pathways. Thus, it should be demonstrated that any proposed piling will not result in contamination of groundwater.

Dewatering

Dewatering is the removal/abstraction of water (predominantly, but not confined to, groundwater) to locally lower water levels near the excavation. This can allow operations to take place, such as mining, quarrying, building, engineering works or other operations, whether underground or on the surface. Any dewatering activities on-site could have an impact upon local wells, water supplies and/or nearby watercourses and environmental interests. This activity was previously exempt from requiring an abstraction licence. From 1 January 2018, most cases of newly planned dewatering operations above 20 cubic metres a day will require a water abstraction licence from us

prior to the commencement of dewatering activities at the site. More information is available on gov.uk:

<https://www.gov.uk/guidance/water-management-apply-for-a-water-abstraction-or-impoundment-licence#apply-for-a-licence-for-a-previously-exempt-abstraction>.

Regulatory position statements

Discharges from dewatering to surface water or groundwater will require an Environmental Permit unless you can meet the conditions of the RPS or exemptions or exclusions for groundwater activities. The following Regulatory Position Statement will apply: 'Temporary dewatering from excavations to surface water.'

<https://www.gov.uk/government/publications/temporary-dewatering-from-excavations-to-surface-water>

Please send me a copy of the decision notice and forward a copy of this letter to the applicant.

Yours sincerely

Mrs. SYLVIA WHITTINGHAM
Planning Advisor

SPPlanning.RFH@environment-agency.gov.uk