

From: Scott, Judith
Sent: 14 December 2022 09:52
To: Clapworthy, Dean <D.Clapworthy@bury.gov.uk>
Subject: RE: Initial Consultation on Planning Application 68999

Hi Dean

Please find my comments below.

CONTAMINATED LAND – CONDITION.

The site has previously been in use as open land prior to being developed as a terraced residential property by 1930. Surrounding historical uses include a Public House, a car sales garage and residential properties. The site is situated above the Upper Coal Measures Sedimentary Rocks and the Manchester Marls Formation Secondary A Aquifer which is overlain by Glaciofluvial Deposits. The site is not within 250m of a registered landfill.

The site is situated in close proximity to an Air Quality Management Area.

In line with the National Planning Policy Framework, the site is proposed for a sensitive end use we recommend that the following contaminated land conditions are placed on any grant of permission:

CLA5 - Unforeseen Contamination 2 (where CLA1 and CLA2 are NOT on as conditions).

Reason: This is to secure the satisfactory development of the site in terms of human health, controlled waters and the wider environment and pursuant to the National Planning Policy Framework.

AIR QUALITY – CONDITION

Bury Council has been identified by DEFRA as an area requiring to significantly improve air quality. The required measures to do this are currently under discussion. Due to this requirement, this Section recommends the following condition to be placed on any grant of permission:

EV Charging provision – COMMENT

Bury Council has been identified by DEFRA as an area requiring to significantly improve air quality. The required measures to do this are currently under discussion. Due to this requirement, and the requirements of the new building regulations (The Building Regulations 2010, Approved Document S, Infrastructure for the charging of electric vehicles), please supply details of the proposed provision for electric vehicle charging.

INFORMATIVE - The Control of Noise (Appeals) Regulations 1975, Section 60. Control of Noise on Construction Sites

Works carried out in connection with the planning permission shall comply with the above regulations which require the following:

1. All works and ancillary operations which are audible at the boundary of the nearest house or noise receptor, or at such other place as may be agreed with the Council, shall be carried out only between the hours of 0800 and 1800 on

Mondays to Fridays and between the hours of 0900 and 1400 on Saturdays and at no time on Sundays and Bank Holidays.

2. The best practicable means, as defined in section 72 of the Control of Pollution Act 1974, to reduce noise to a minimum shall be employed at all times.
3. All plant and machinery in use shall be properly silenced and maintained in accordance with the manufacturer's instructions.
4. Any emergency deviation from the above (1 – 3) shall be notified to Bury Council without delay.

Any contravention of these requirements will trigger the serving of a Notice under Section 60 of The Control of Noise Regulations 1975.

Thank you

**Operations – Environment Section.
14 December 2022**