

73159

EH comment

The noise assessment states that there will be no amplified sound so this sound be a condition as the assessment did not take this into account. The mitigation in the conclusion of the report states that additional Hush panel acoustic lining to the party wall.

The assessment states that the synagogue open from 07:00 -23:00 whereby people coming and going could raise noise levels out of the normal working day hours 08:00 -18:00.

Unit Manager, Environmental Health Commercial Team
Bury Council | Public Protection Service
3 Knowsley Place | Duke Street | Bury | BL9 0EJ