

73223

EH comments

The noise assessment has identified mitigation pg 33

A noise management plan shall be implemented

Noise from whistles could be suitably mitigated by either:

- A 2m high barrier along the western side of the AGP. A barrier must be close-boarded with no gaps and have a minimum mass of 10kg/m².
- A no whistle policy. Only for competitive matches

Unit Manager, Environmental Health Commercial Team
Bury Council | Public Protection Service
3 Knowsley Place | Duke Street | Bury | BL9 0EJ