

72418

EH comments

The application and additional supplementary documents have included commercial kitchen odour and noise following guidance of the HVCA standard DW172 and DEFRA guidance on control of odour and noise for commercial kitchens. This includes noise suppression for the potential of vibration from the extract fan and ductwork.

The noise assessment has specified plant noise limits based upon the principles of BS4142

Unit Manager, Environmental Health Commercial Team
Bury Council | Public Protection Service
3 Knowsley Place | Duke Street | Bury | BL9 0EJ