

68245 – Tottington Manor Farm.

Comments from Building Control

- Provide evidence that existing foundations and floor slab are suitable to support the necessary upgrade works required to the walls and roof. They could be evidence exposing the foundation construction at two trial hole sites and following this the provision report from a suitable qualified Structural Engineer.
- Provide further evidence that the existing roof structure will remain stable following the conversion works and indicate the proposed method of upgrading this element to comply with the Building Regulations.
- Provide construction details for the proposed wall upgrade with details showing compliance with the Building Regulations.