


Conway Architectural Design shall have no responsibility for any use made of this document other than for that which it was prepared and issued. This drawing should not be scaled. Work to figured dimensions only.
All dimensions and levels to be checked on site. No building work is to be started until all relevant approvals are in place.
Any discrepancies should be reported to Conway Architectural Design.
This drawing should not be reproduced without written permission from Conway Architectural Design.
Standard Building Regs Notes are to be provided by Conway Architectural Design prior to a building regs application being submitted.



To cheeks and gable of dormer fix terracotta horizontal tiles on 50x25 battens, on Kingspan Nilvent breathable membrane, on 9mm OSB. 75mm Kingspan Kooltherm K7 insulation between 150x50mm timber dormer studs. Lined internally with 52.5mm Kingspan Kooltherm K118 insulated plasterboard with 3mm skim coat. To give a U-Value of 0.18w/m²k.

Where dormer wall is within 1 metre of boundary then Supalux board is to be used instead of 9mm OSB. To give 60mins fire resistance.

Drains from new en-suite to connect into existing soil pipe used for existing bathroom below.

Build up existing gable in brickwork outer leaf to match existing, 75mm full fill Knauf Dritherm Slab 34 insulation in cavity, 100mm medium density blockwork inner leaf with 75mm insulated plasterboard. U-Value of 0.17 W/m²K.

New timber staircase from first to second floor to have a going of 245mm 12no. equal risers, max 220mm riser(max staircase angle of 42°) with a minimum clear headroom of 2m. Balustrade to 1 side of stair min. 900mm above pitch.

Structural engineer to design new steel ridge beam.

Build new stud walls in 75x50mm timber stud, 1 layer of 12mm ply and 1 layer of 12.5mm plasterboard and skim to both sides. Fill cavity between studs in mineral wool insulation for acoustic purposes.

Storage area in eaves to be accessed through low level door opening in new stud wall.

Structural engineer to design new steel purlin to replace existing purlin.

New loft floor to be installed. use 175x75mm C24 joists at 400mm centres. New 18mm ply boarding on top of joists. Line underside where required with 12.5mm plasterboard and skim. Use 150mm Rockwool mineral insulation between joists. Structural engineer to confirm floor joists sizes and any required support steelwork. Add floor boards to storage areas.

- **HD** Indicates heat detector.
- **SD** Indicates smoke detector.
- FD30** 30min fire door.

Conway Architectural Design

6 Conway Close
Alkington
Middleton
Manchester, M24 1EW
E: conway-design@outlook.com

JOB TITLE :	Hip To Gable Dormer Loft Conversion
ADDRESS :	11 Stretton Road, Greenmount, Bury
DRAWING TITLE :	Proposed Loft Floor Plan
SCALE :	1:50 @ A3
DRAWN : xxx	DATE : 27.03.24