


Conway Architectural Design shall have no responsibility for any use made of this document other than for that which it was prepared and issued. This drawing should not be scaled. Work to figured dimensions only.
All dimensions and levels to be checked on site. No building work is to be started until all relevant approvals are in place. Any discrepancies should be reported to Conway Architectural Design. This drawing should not be reproduced without written permission from Conway Architectural Design. **Standard Building Regs Notes are to be provided by Conway Architectural Design prior to a building regs application being submitted.**



Cold flat roof to be constructed in single ply rubber membrane waterproof top layer, 18mm plywood deck, on 50x50mm cross battens for cross flow ventilation, on 170x75mm C24 roof joists at 400mm centres.
100mm Kingspan Kooltherm TR27 insulation between joists leaving a min. 50mm airgap above insulation. Roof joists underdrawn with 50mm Kingspan Kooltherm TR27 insulation between timber battens, then vapour control layer and 12.5mm plasterboard and skim.
To give a U-Value of 0.15w/m²

New velux rooflights to be fitted to manufacturers instructions, rafters to be doubled up around openings.

Add timber battens to run with underside of existing rafters, to increase depth of existing rafters, to allow for substantial thickness of insulation between rafters. Insulation to existing pitched roof to allow for minimum 50mm air gap above 125mm Kingspan Kooltherm K7 insulation between rafters and 62.5mm Kingspan Kooltherm K118 insulated plasterboard under rafters. Insulation to continue down to eaves level, to give a warm storage area.
U value of roof = 0.15W/m²K.

New rafters to be 175x50mm C16 timbers at 400mm centres.
Depth of rafters to be 175mm to enable 125mm insulation between rafters. Whilst it is acknowledged that 150mm depth rafters will achieve the correct spans for the roof.

Conway Architectural Design

6 Conway Close
Alkrington
Middleton
Manchester, M24 1EW
E: conway-design@outlook.com

JOB TITLE :
ADDRESS :
DRAWING TITLE :
SCALE :
DRAWN : xxx

Hip To Gable Dormer Loft Conversion
11 Stretton Road, Greenmount, Bury
Proposed Roof Plan
1:50 @ A3
DATE : 27.03.24