

From: Lee, Christine E

Sent: Wednesday, September 13, 2023 2:39 PM

To: Booth, Claire

Cc: Gabrielli, Luca

Subject: RE: Application update request - 69932 - URGENT - DECISION DUE!

Claire

Environmental Health recommend refusal

The noise survey is inadequate it does not comply with BS4142.

It is not clear if an extraction system will be provided, if the windows are to be openable for ventilation or if there will be an alternative means of ventilation.

There is insufficient toilet provision at least 2 toilets should be provided either 1 male and 1 female or fully separated cubicles with wash hand facilities for each.

There is no facility for waste storage within the property boundary

Christine