

Design for security comments

Having looked at the proposals I am satisfied that the recommendations made within the CIS have been largely implemented. We have been thoroughly consulted and involved pre-planning to identify and mitigate against the potential risks.

The electronic bollard restricting access to Union Square is not in use and could become an unofficial drop-off/pick-up for the Metrolink station (particularly during the reconstruction of the interchange building), which the space is not designed for, and could potentially leave pedestrians entering and leave the bridge vulnerable.

Recommend that the operation of this bollard is reinstated prior to the bridge being used.

Design for Security Consultant

Greater Manchester Police| Crime Prevention Team

design**forsecurity**