

TEST REPORT

Client Wardell Armstrong LLP

Address Sir Henry Doulton House
Forge Lane
Etruria
Stoke on Trent
ST1 5BD

Contract Pilsworth

Job Number MRN 24066/7
Date of Issue 15 March 2024
Page 1 of 4

Approved Signatories

S J Hutchings, O P Davies

Notes

- 1 All remaining samples and remnants from this contract will be disposed 28 days from the date of this report unless you notify us to the contrary.
- 2 Result certificates, in this report, not bearing a UKAS mark, are not included in our UKAS accreditation schedule.
- 3 Opinions and interpretations expressed herein are outside the scope of our UKAS accreditation.
- 4 Certified that the samples have been examined and tested in accordance with the terms of the contract/order and unless otherwise stated conform to the standards/specifications quoted.
- 5 The results included within the report are representative of the samples submitted for analysis.
- 6 This certificate should not be reproduced, except in full, without the express permission of the laboratory.



Andrew House, Hadfield Street, Dukinfield, Cheshire SK16 4QX Tel: 0161 475 0870
Email: enquiries@murrayrix.com Website: www.murrayrix.com

Also at: London: 020 8523 1999

Murray Rix is the trading name of Murray Rix (Northern) Limited. Registered in England 2878361

TEST CERTIFICATE
PARTICLE SIZE DISTRIBUTION

BS EN ISO 17892-4:2016


Determination of Water Content in accordance with BS EN ISO 17892-1:2014+A1:2022 (Oven Dry)

CLIENT	Wardell Armstrong LLP
SITE	Pilsworth
JOB NUMBER	MRN 24066/7

SAMPLE LABEL	TP1 1.5m	DATE SAMPLED	13-Feb-24
LAB SAMPLE No	425401	DATE RECEIVED	15-Feb-24
DATE TESTED	19-Feb-24	SAMPLED BY	Client

MATERIAL	Brown silty slightly gravelly SAND
ADVISED SOURCE	Site Investigation Sample

Sieve Size (mm)	% Passing (%)	Specification (%)	Sieve Size (mm)	% Passing (%)	Specification (%)
125	100		5	100	
90	100		2	100	
75	100		0.6	93	
50	100		0.425	69	
37.5	100		0.3	41	
20	100		0.2	20	
14	100		0.15	15	
10	100		0.063	8	



REMARKS

SIGNED



NAME

O.P. Davies BA (Hons)
(Laboratory Manager)

DATE

15-Mar-24

TEST CERTIFICATE
PARTICLE SIZE DISTRIBUTION

BS EN ISO 17892-4:2016


Determination of Water Content in accordance with BS EN ISO 17892-1:2014+A1:2022 (Oven Dry)

CLIENT	Wardell Armstrong LLP
SITE	Pilsworth
JOB NUMBER	MRN 24066/7

SAMPLE LABEL	TP2 1.5m	DATE SAMPLED	13-Feb-24
LAB SAMPLE No	425402	DATE RECEIVED	15-Feb-24
DATE TESTED	19-Feb-24	SAMPLED BY	Client

MATERIAL	Brown silty slightly gravelly SAND
ADVISED SOURCE	Site Investigation Sample

Sieve Size (mm)	% Passing (%)	Specification (%)	Sieve Size (mm)	% Passing (%)	Specification (%)
125	100		5	100	
90	100		2	100	
75	100		0.6	95	
50	100		0.425	46	
37.5	100		0.3	18	
20	100		0.2	7	
14	100		0.15	6	
10	100		0.063	3	



REMARKS

SIGNED



NAME

O.P. Davies BA (Hons)
(Laboratory Manager)

DATE

15-Mar-24

TEST CERTIFICATE
PARTICLE SIZE DISTRIBUTION

BS EN ISO 17892-4:2016


Determination of Water Content in accordance with BS EN ISO 17892-1:2014+A1:2022 (Oven Dry)

CLIENT	Wardell Armstrong LLP
SITE	Pilsworth
JOB NUMBER	MRN 24066/7

SAMPLE LABEL	TP6 1.0m	DATE SAMPLED	13-Feb-24
LAB SAMPLE No	425403	DATE RECEIVED	15-Feb-24
DATE TESTED	19-Feb-24	SAMPLED BY	Client

MATERIAL	Brown silty gravelly SAND
ADVISED SOURCE	Site Investigation Sample

Sieve Size (mm)	% Passing (%)	Specification (%)	Sieve Size (mm)	% Passing (%)	Specification (%)
125	100		5	89	
90	100		2	85	
75	100		0.6	78	
50	100		0.425	62	
37.5	100		0.3	38	
20	94		0.2	26	
14	94		0.15	21	
10	92		0.063	17	



REMARKS

SIGNED



NAME

O.P. Davies BA (Hons)
(Laboratory Manager)

DATE

15-Mar-24