

**72763**

**EH comment**

The noise assessment has identified mitigation methods which must be incorporated in the development.

Building fabric - double skinned external brick, plaster Rw 55-58dB

Glazing of the noise-sensitive rooms,

Bedroom minimum single figure weighted sound reduction 38dB

Living rooms minimum single figure weighted sound reduction 34dB

Kind regards

A handwritten signature in black ink, appearing to read 'Rob Hall', with a stylized, cursive script.

**Rob Hall**

Unit Manager, Environmental Health Commercial Team

Bury Council | Public Protection Service