

BURY COUNCIL
DEPARTMENT FOR OPERATIONS

REF NO: 22/055

FROM: Head of Engineering

TO: Head of Development Management

Planning Application No: 68015

Location: 185 Rochdale Road, Pimhole, Bury, BL9 7BB

Development: Internally illuminated fascia sign

RECOMMENDATION

I recommend that any planning permission given shall include the following condition:

The luminance of the fascia sign shall not exceed 150cd/m². (ADL4 Amended)

Reasons

To avoid undue distraction to traffic in the interests of road safety and to protect the amenity of adjoining occupiers.

Comments and Observations

Date: 21 April 2022

Signed: **A Southgate**
(pp) Head of Engineering

HIGHWAYS ASPECTS ONLY