

Drainage Engineer

Following review of the submitted Flood Risk Assessment and Drainage Strategy, clarification is required to confirm the existing surface water discharge rate and regime from the site, and to demonstrate that the proposed restricted discharge rate would result in no increase in surface water runoff when compared to the existing scenario, or alternatively would achieve an appropriate level of hydraulic betterment, in line with local policy.