

Technical Specifcication:

Regarding the technical specification for the Biomass installations/ hopper/ flues, please see information below from the Engineer.

- *There will be 6x new Froling P4 99kW boilers that have an Airborne sound level specified as <70 dB(A) (pg. 21/22 of P4 8-105 Installation Manual),*
- *There will be 1x new Froling T4e 130kW that have an Airborne sound level specified as <70 dB(A) (pg. 23 of Installation Manual T4e_20-180_en),*
- *There are 2x existing Propel 99kW Boilers, which are being relocated, unfortunately we don't have any manuals for these.*