

SECTION A-A
1:20 @ A1

PROPOSED GROUND FLOOR WALLS SHOWING FIRST FLOOR LEVEL STRUCTURE OVER
1:50 @ A1

1. THIS DRAWING MUST NOT BE SCALED BY EITHER CONTRACTORS OR OTHER CONSULTANTS ANY DIMENSIONAL OR SETTING - OUT DISCREPANCIES ARE TO BE REPORTED PRIOR TO CONSTRUCTION / FABRICATION.
2. THIS DRAWING MUST BE READ IN CONJUNCTION WITH THE RELEVANT SPECIFICATIONS TOGETHER WITH THE APPROPRIATE ARCHITECTS AND SERVICES CONSULTANTS DRAWINGS AND SPECIFICATIONS.
3. ALL MORTAR ABOVE D. P. C. LEVEL TO BE CLASS (III) MORTAR - 1 : 1 : 6 CEMENT : LIME : SAND U. N. O.
4. ALL MORTAR BELOW D. P. C. LEVEL TO BE CLASS (I) MORTAR - 1 : 0.25 : 3 CEMENT : LIME : SAND U. N. O.
5. FACING BRICK TO BE SPECIFIED BY THE ARCHITECT BUT IS TO HAVE A MINIMUM COMPRESSIVE STRENGTH OF 10 N/MM²
6. STAINLESS STEEL WALL TIES ARE TO BE PROVIDED AT 750 HORIZONTAL AND 450 VERTICAL CENTRES IN A STAGGERED PATTERN. TIES TO BE PROVIDED AT 225 VERTICAL CENTRES ADJACENT OPENINGS
7. ALL STEEL TO BE GRADE S275 U.N.O. AND ALL FABRICATION TO BE IN ACCORDANCE WITH B.S. 5950
8. ALL STEELWORK TO BE PAINTED WITH ONE COAT OF HIGH BUILD ZINC PHOSPHATE PRIMER TO GIVE A D.F.T. OF 75 MICRONS
9. STEELWORK IN CAVITIES OR EXTERNAL TO BE HOT DIP GALVANISED
10. MASS CONCRETE FOR FOUNDATIONS TO BE GRADE ST20 WITH A MINIMUM CEMENT CONTENT OF 240kg/M³ AND A MAX WATER/CEMENT RATIO OF 0.7.

DETAIL A
1:10 @ A1

DETAIL B
1:10 @ A1

DETAIL C
1:10 @ A1



CLIENT:	
JOE & HAYLEY CARROLL	
PROJECT:	
113 HEYWOOD OLD ROAD	
TITLE:	
GENERAL ARRANGEMENT	
SCALE:	DATE:
AS SHOWN	APR 25
DRAWING NUMBER:	REVISION:
J154 / 01	