

EH comment

CCooking Fumes (the 'HOT5')

- No development shall commence unless and until a scheme for treating, diluting and dispersing fumes and odours has been submitted to and approved in writing by the Local Planning Authority. The scheme submitted shall include a written statement from a suitably qualified person who is a member of the Heating and Ventilation Contractors Association (HVCA) or an equivalent professional body, stating that the fume treatment to be installed complies with or exceeds the 'Minimum Requirements For Odour Control' provided by the Guidance on the Control of Odour and Noise from Commercial Kitchen Exhaust Systems :DEFRA 2005 (or if applicable such superseding guidance as shall prevail at the time of commencement of the development).

The scheme to be submitted shall also include the relevant manufacturer and installer instructions for any associated equipment with details of maintenance requirements.

The scheme as approved shall be implemented, available for use and maintained in accordance with the approved scheme whilst it shall serve the development.

Reason. To protect the residential amenities of nearby residential property from impact upon from fumes and odour pursuant to UDP Policy S2/6 - Food and Drink.

ALSO,s

The installation shall be so designed such that the maximum noise emitted does not exceed NR25 (Noise Rating) in the bedrooms of the nearest residential property, with the windows of that residential property being open in the normal manner for ventilation purposes.

The scheme as approved shall be fully implemented and aall equipment installed shall be used and maintained in accordance with the manufacturers and installers instructions.

Reason – To protect the residential amenities of nearby residential property from impact upon from fumes and odour pursuant to UDP Policy S2/6 - Food and Drink.

Environmental Health Commercial Team
Bury Council | Public Protection Service