

From: Hall, Rob A <bury.gov.uk>

Sent: Thursday, January 4, 2024 10:54 AM

To: Booth, Claire <bury.gov.uk>

Subject: RE: 69164: Former Texaco Garage site, Bury Old Road - Amendments received

Claire

The noise assessment (BS4142) indicates a low impact to the nearest resident from No2 condensing units and therefore the planning application should be granted from EH/noise perspective

Regards

Rob Hall

Unit Manager, Commercial Team

Bury Council | Department for Operations | Public Protection

3 Knowsley Place | Duke Street | Bury | BL9 0EJ