

Bury MBC
Craig House 5 Bank Street
Bury
BL9 0DN

Your ref: 67243
Our ref: DC/21/3288
Date: 17-AUG-21

Dear Sir/Madam,

Location : Land off Brownhills Close / Bury Road, Tottington

Proposal : Erection of 8 dwellings, new/improved formal & informal community open space/play space

With regards to the above development proposal, United Utilities Water Limited ('United Utilities') wishes to provide the following comments.

Drainage

In accordance with the National Planning Policy Framework (NPPF) and the National Planning Practice Guidance (NPPG), the site should be drained on a separate system with foul water draining to the public sewer and surface water draining in the most sustainable way.

In the absence of a detailed foul and surface water drainage scheme we would kindly request that if you are minded to grant Planning Consent for the above development that the condition and advisory notes provided below are included within the consent.

Condition 1 – Surface water

As part of the submission of the first reserved matters application, details of a sustainable surface water drainage scheme and a foul water drainage scheme shall be submitted to and approved in writing by the Local Planning Authority. The drainage schemes must include:

(i) An investigation of the hierarchy of drainage options in the National Planning Practice Guidance (or any subsequent amendment thereof). This investigation shall include

evidence of an assessment of ground conditions, the potential for infiltration of surface water in accordance with BRE365;

(ii) A restricted rate of discharge of surface water agreed with the local planning authority (if it is agreed that infiltration is discounted by the investigations).

(iii) Levels of the proposed drainage systems including proposed ground and finished floor levels in AOD;

(iv) Incorporate mitigation measures to manage the risk of sewer surcharge; and

(v) Foul and surface water shall drain on separate systems within the site.

The approved schemes shall also be in accordance with the Non-Statutory Technical Standards for Sustainable Drainage Systems (March 2015) or any subsequent replacement national standards and no surface water shall discharge to the public sewer either directly or indirectly.

Prior to occupation of the proposed development, the drainage schemes shall be completed in accordance with the approved details and retained thereafter for the lifetime of the development.

Reason: To promote sustainable development, secure proper drainage and to manage the risk of flooding and pollution.

Condition 2 – Foul water

Foul and surface water shall be drained on separate systems.

Reason: To secure proper drainage and to manage the risk of flooding and pollution.

The applicant can discuss any of the above with Developer Engineer, **Rob Brenton**, by email at wastewaterdeveloperservices@uuplc.co.uk.

Please note, United Utilities are not responsible for advising on rates of discharge to the local watercourse system. This is a matter for discussion with the Lead Local Flood Authority and / or the Environment Agency (if the watercourse is classified as main river).

If the applicant intends to offer wastewater assets forward for adoption by United Utilities, the proposed detailed design will be subject to a technical appraisal by an Adoptions Engineer as we need to be sure that the proposal meets the requirements of Sewers for Adoption and United Utilities' Asset Standards. The detailed layout should be prepared with consideration of what is necessary to secure a development to an adoptable standard. This is important as drainage design can be a key determining factor of site levels and layout. The proposed design should give consideration to long term operability and give United Utilities a cost effective proposal for the life of the assets. Therefore, should this application be approved and the applicant wishes to progress a Section 104 agreement, we strongly

recommend that no construction commences until the detailed drainage design, submitted as part of the Section 104 agreement, has been assessed and accepted in writing by United Utilities. Any works carried out prior to the technical assessment being approved is done entirely at the developers own risk and could be subject to change.

Management and Maintenance of Sustainable Drainage Systems

Without effective management and maintenance, sustainable drainage systems can fail or become ineffective. As a provider of wastewater services, we believe we have a duty to advise the Local Planning Authority of this potential risk to ensure the longevity of the surface water drainage system and the service it provides to people. We also wish to minimise the risk of a sustainable drainage system having a detrimental impact on the public sewer network should the two systems interact. We therefore recommend the Local Planning Authority include a condition in their Decision Notice regarding a management and maintenance regime for any sustainable drainage system that is included as part of the proposed development.

For schemes of 10 or more units and other major development, we recommend the Local Planning Authority consults with the Lead Local Flood Authority regarding the exact wording of any condition. You may find the below a useful example:

Prior to occupation of the development a sustainable drainage management and maintenance plan for the lifetime of the development shall be submitted to the local planning authority and agreed in writing. The sustainable drainage management and maintenance plan shall include as a minimum:

- a. Arrangements for adoption by an appropriate public body or statutory undertaker, or, management and maintenance by a resident's management company; and*
- b. Arrangements for inspection and ongoing maintenance of all elements of the sustainable drainage system to secure the operation of the surface water drainage scheme throughout its lifetime.*

The development shall subsequently be completed, maintained and managed in accordance with the approved plan.

Reason: To ensure that management arrangements are in place for the sustainable drainage system in order to manage the risk of flooding and pollution during the lifetime of the development.

Please note United Utilities cannot provide comment on the management and maintenance of an asset that is owned by a third party management and maintenance company. We would not be involved in the discharge of the management and maintenance condition in these circumstances.

Water Supply

We can readily supply water for domestic purposes, but for larger quantities for example, commercial/industrial we will need further information.

Although water supply in the area is compliant with current regulatory standards, we recommend the applicant provides water storage of 24 hours capacity to guarantee an adequate and constant supply.

The applicant must undertake a complete soil survey, as and when land proposals have progressed to a scheme design i.e. development, and results submitted along with an application for water. This will aid in our design of future pipework and materials to eliminate the risk of contamination to the local water supply.

If the applicant intends to obtain a water supply from United Utilities for the proposed development, we strongly recommend they engage with us at the earliest opportunity. If reinforcement of the water network is required to meet the demand, this could be a significant project and the design and construction period should be accounted for.

To discuss a potential water supply or any of the water comments detailed above, the applicant can contact the team at [**DeveloperServicesWater@uuplc.co.uk**](mailto:DeveloperServicesWater@uuplc.co.uk).

Please note, all internal pipework must comply with current Water Supply (water fittings) Regulations 1999.

United Utilities' Property, Assets and Infrastructure

The applicant should be aware of water mains in the vicinity of the proposed development site. Whilst this infrastructure is located outside the applicant's proposed red line boundary, the applicant must comply with our 'Standard Conditions for Works Adjacent to Pipelines'. We provide this information to support the applicant in identifying the potential impacts from all construction activities on United Utilities infrastructure and to identify mitigation measures to protect and prevent any damage to this infrastructure both during and after construction. This includes advice regarding landscaping in the vicinity of pipelines.

A public sewer crosses this site and we will not permit building over it. We will require an access strip width of six metres, three metres either side of the centre line of the sewer which is in accordance with the minimum distances specified in the current issue of Part H of the Building Regulations, for maintenance or replacement. Therefore a modification of the site layout, or a diversion of the affected public sewer may be necessary. All costs associated with sewer diversions must be borne by the applicant.

To establish if a sewer diversion is feasible, the applicant must discuss this at an early stage with our Developer Engineer at wastewaterdeveloperservices@uuplc.co.uk as a lengthy lead in period may be required if a sewer diversion proves to be acceptable.

Deep rooted shrubs and trees should not be planted in the vicinity of the public sewer and overflow systems.

Where United Utilities' assets exist, the level of cover to the water mains and public sewers must not be compromised either during or after construction.

For advice regarding protection of United Utilities assets, the applicant should contact the teams as follows:

Water assets – DeveloperServicesWater@uuplc.co.uk

Wastewater assets – WastewaterDeveloperServices@uuplc.co.uk

It is the applicant's responsibility to investigate the possibility of any United Utilities' assets potentially impacted by their proposals and to demonstrate the exact relationship between any United Utilities' assets and the proposed development.

A number of providers offer a paid for mapping service including United Utilities. To find out how to purchase a sewer and water plan from United Utilities, please visit the Property Searches website; <https://www.unitedutilities.com/property-searches/>

You can also view the plans for free. To make an appointment to view our sewer records at your local authority please contact them direct, alternatively if you wish to view the water and the sewer records at our Lingley Mere offices based in Warrington please ring [0370 751 0101](tel:03707510101) to book an appointment.

Due to the public sewer transfer in 2011, not all sewers are currently shown on the statutory sewer records and we do not always show private pipes on our plans. If a sewer is discovered during construction; please contact a Building Control Body to discuss the matter further.

Should this planning application be approved the applicant should contact United Utilities regarding a potential water supply or connection to public sewers. Additional information is available on our website <http://www.unitedutilities.com/builders-developers.aspx>

Yours faithfully

Jill Walker
Planning Analyst
Planning, Landscape and Ecology