

Bury Council
By email

Your ref: 68608
Our ref: DC/22/2637
Date: 25-AUG-22

Dear Planning Team

Location : Land adjacent to 391 Whalley Road, Shuttleworth, Ramsbottom, Bury, BL0 0ER
Proposal : Demolition of existing garages and Erection of 2 no. semi-detached dwellings with associated parking

United Utilities wish to make the following comments regarding the proposal detailed above.

Summary

According to our records a large diameter trunk main and public sewer crosses the site. Following our review of the proposed site layout, we have concerns regarding the proximity of proposed development to our wastewater and water assets. To resolve this matter, and to avoid any unnecessary costs or delays to either the applicant or any future developer, we request the applicant submits a detailed site layout plan which overlays the proven location of the sewer and water main in relation to any proposed development (including walls, fencing, parking etc.).

Without this information we are unable to provide further comment and there is a risk that as the scheme progresses, the applicant, or any subsequent developer, may discover that their plans are not implementable in their existing form or that diversion of assets is required. Therefore, we strongly recommend this matter is resolved PRIOR TO DETERMINATION.

The applicant or developer should contact our Developer Services team to discuss. Please see 'Contacts' section below.

UNITED UTILITIES PROPERTY, ASSETS AND INFRASTRUCTURE

Water pipelines

United Utilities will not allow building over or in close proximity to a water main.

A large diameter trunk main crosses the site. It must not be built over, or our access to the pipeline compromised in any way. The Water Industry Act 1991 affords United Utilities specific rights in relation to maintenance, repair, access and protection of our water infrastructure. We require an access strip as detailed in our 'Standard Conditions for Works Adjacent to Pipelines', a copy of which accompanies this letter. The applicant must comply with this document to ensure pipelines are adequately protected both during and after the construction period. It also includes advice regarding landscaping in the vicinity of pipelines.

Given the size and nature of the pipeline concerned, we strongly recommend that if they have not already done so, the applicant contacts our Developer Services team at the earliest opportunity for advice on determining the precise location of the pipeline and additional protection measures they must consider both during and after construction. See Contacts section below.

Should the Council deem this application suitable for approval we request the following condition is included in the subsequent Decision Notice to afford appropriate protective measures for this asset:

CONDITION

No construction shall commence until details of the means of ensuring the water main that is laid within the site boundary is protected from damage as a result of the development have been submitted to and approved by the Local Planning Authority in writing. The details shall outline the potential impacts on the water main from construction activities and the impacts post completion of the development on the water main infrastructure that crosses the site and identify mitigation measures to protect and prevent any damage to the water main both during construction and post completion of the development. Any mitigation measures shall be implemented in full in accordance with the approved details.

Reason: In the interest of public health and to ensure protection of the public water supply.

Wastewater pipelines

United Utilities will not allow a new building to be erected over or in close proximity to a public sewer or any other wastewater pipeline. This will only be reviewed in exceptional circumstances. *Nb. Proposals to extend domestic properties either above, or in close proximity to a public sewer will be reviewed on a case by case basis by either by a building control professional or following a direct application to United Utilities (see our website for further details).*

A public sewer crosses the site and we may not permit building over it. We require an access strip for maintenance or replacement. The minimum distances that might be acceptable to United Utilities are detailed within Part H of the Building Regulations however, we recommend the applicant determines the precise location, size, depth and condition of the pipeline as this is likely to influence the required stand-off distance from any structure.

Advice relating to both water and wastewater infrastructure

It is the applicant's responsibility to demonstrate the exact relationship between United Utilities' assets and the proposed development. Developer's should investigate the existence and the precise location of water and wastewater pipelines as soon as possible as this could significantly impact the preferred site layout and/or diversion of the asset(s) may be required. Where United Utilities' assets cross the proposed red line boundary, developers must contact our Developer Services team prior to commencing any works on site, including trial holes, groundworks or demolition.

Unless there is specific provision within the title of the property or an associated easement, any necessary disconnection or diversion of assets to accommodate development, will be at the applicant/developer's expense. In some circumstances, usually related to the size and nature of the assets impacted by proposals, developers may discover the cost of diversion is prohibitive in the context of their development scheme.

Any agreement to divert our underground assets will be subject to a diversion application, made directly to United Utilities. This is a separate matter to the determination of a planning application. We will not guarantee, or infer acceptance of, a proposed diversion through the planning process (where diversion is indicated on submitted plans). In the event that a diversion application is submitted to United Utilities and subsequently rejected (either before or after the determination of a planning application), applicants should be aware that they may need to amend their proposed layout to accommodate United Utilities' assets.

Where United Utilities' assets exist, the level of cover to United Utilities pipelines and apparatus must not be compromised either during or after construction and there should be no additional load bearing capacity on pipelines without prior agreement from United Utilities. This would include earth movement and the transport and position of construction equipment and vehicles.

Any construction activities in the vicinity of United Utilities' assets must comply with national building and construction standards and where applicable, our 'Standard Conditions for Works Adjacent to Pipelines'. This includes United Utilities' assets which may be located outside the applicant's red line boundary.

The applicant or developer should contact our Developer Services team for advice if their proposal is in the vicinity of water or wastewater pipelines and apparatus. It is their responsibility to ensure that United Utilities' required access is provided within their layout and that our infrastructure is appropriately protected. The developer would be liable for the cost of any damage to United Utilities' assets resulting from their activity. Please see 'Contacts' section below.

DRAINAGE

National Planning Policy Framework (NPPF) and the National Planning Practice Guidance (NPPG) advise that surface water from new developments should be investigated and delivered in the following order of priority:

1. into the ground (infiltration);
2. to a surface water body;

3. to a surface water sewer, highway drain, or another drainage system;
4. to a combined sewer.

We recommend the applicant considers their drainage plans in accordance with the drainage hierarchy outlined above.

Please note, United Utilities is not responsible for advising on rates of discharge to the local watercourse system. This is a matter for discussion with the Lead Local Flood Authority and / or the Environment Agency (if the watercourse is classified as main river).

In the event that the applicant, or any subsequent developer, approaches United Utilities regarding a connection for surface water to the public sewer, it is likely that we will request evidence that the drainage hierarchy has been fully investigated and why more sustainable options are not achievable. This will be managed through either our 'S106 Sewer Connections' or 'S104 Adoptions' processes.

If the applicant intends to offer wastewater assets forward for adoption by United Utilities, their proposed detailed design will be subject to a technical appraisal by our Developer Services team and must meet the requirements outlined in 'Sewers for Adoption and United Utilities' Asset Standards'. This is important as drainage design can be a key determining factor of site levels and layout.

The applicant should not presume that the principles outlined within a drainage strategy will meet the detailed requirements for a successful adoption application. We strongly recommend that no construction commences until the detailed drainage design, has been assessed and accepted in writing by United Utilities. Any works carried out prior to the technical assessment being approved is done entirely at the developers own risk and could be subject to change.

WATER AND WASTEWATER SERVICES

If the applicant intends to receive water and/or wastewater services from United Utilities, they should visit our website or contact the Developer Services team for advice. This includes seeking confirmation of the required metering arrangements for the proposed development. See 'Contacts' Section below.

If the proposed development site benefits from existing water and wastewater connections, the applicant should not assume that the arrangements will be suitable for the new proposal.

In some circumstances we may require a compulsory meter is fitted. For detailed guidance on whether the development will require a compulsory meter please visit <https://www.unitedutilities.com/my-account/your-bill/our-household-charges-20212022/> and go to section 7.7 for compulsory metering.

If reinforcement of the water network is required to meet potential demand, this could be a significant project and the design and construction period should be accounted for.

To avoid any unnecessary costs and delays being incurred by the applicant or any subsequent developer, we strongly recommend the applicant seeks advice regarding water and wastewater services, and metering arrangements, at the earliest opportunity. Please see 'Contacts' section below.

CONTACTS

Website

For detailed guidance on water and wastewater services, including application forms and the opportunity to talk to the Developer Services team using the '**Live Chat**' function, please visit:

<http://www.unitedutilities.com/builders-developers.aspx>

Email

For advice on water and wastewater services or to discuss proposals near to pipelines, email the Developer Services team as follows:

Water mains and water supply, including metering - DeveloperServicesWater@uuplc.co.uk

Public sewers and drainage - WastewaterDeveloperServices@uuplc.co.uk

Telephone - 0345 072 6067

Property Searches (for asset maps):

A number of providers offer a paid for mapping service including United Utilities. For more information, or to purchase a sewer and water plan from United Utilities, please visit <https://www.unitedutilities.com/property-searches/>

Water and sewer records can be viewed for free at our Warrington Head Office by calling 0370 751 0101. Appointments must be made in advance. Public sewer records can be viewed at local authority offices. Arrangements should be made directly with the local authority.

The position of the underground apparatus shown on asset maps is approximate only and is given in accordance with the best information currently available. United Utilities Water will not accept liability for any loss or damage caused by the actual position being different from those shown on the map.

We request that a copy of this letter is made available to the applicant.

Yours faithfully

The Planning, Landscape and Ecology Team