

NOTICE OF PRIOR APPROVAL DETERMINATION

Part 3 of Schedule 2 to The Town and Country Planning (General Permitted Development) (England) Order 2015 (as amended)

To:

Mr Richard Gee
Roman Summer Associates Ltd
Haweswater House
Waterfold Business Park
Bury
BL9 7BR

On Behalf Of:

Mr Derek Abbott
Abbotts Hall
Woodhey Road
Ramsbottom
Bury
BL0 9RD

PART 1 - Particulars of Application

Application Number: 69509

Date of Registration: 28/03/2023

Proposal:

Prior approval of proposed change of use of agricultural building to 3 no. dwellinghouses (Use Class C3)

Location:

Abbotts Hall, Woodhey Road, Ramsbottom, Bury, BL0 9RD

PART 2 - Particulars of Decision

Bury Metropolitan Borough Council hereby determine that prior approval of the local planning authority is **REQUIRED** for the development set out in Part 1 of this decision notice.

The Metropolitan Borough of Bury hereby give **APPROVAL** for the development proposed in the above-mentioned application subject to the following conditions.

- 1 No development shall commence unless and until:-
 - A contaminated land Preliminary Risk Assessment report to assess the actual/potential contamination and/or ground gas/landfill gas risks at the site shall be submitted to, and approved in writing by, the Local Planning Authority;
 - Where actual/potential contamination and/or ground gas/landfill gas risks have been identified, detailed site investigation and suitable risk assessment shall be submitted to, and approved in writing by the Local Planning Authority;
 - Where remediation/protection measures is/are required, a detailed Remediation Strategy shall be submitted to, and approved in writing by, the Local Planning Authority.

Reason. The scheme does not provide full details of the actual contamination and subsequent remediation, which is required to secure the satisfactory development of the site in terms of human health, controlled waters, ground gas and the wider environment and pursuant to National Planning Policy Framework Section 15 - Conserving and enhancing the natural environment.
- 2 Following the provisions of Condition 1 of this planning permission, where remediation is required, the approved Remediation Strategy must be carried out to the satisfaction of the Local Planning Authority within agreed timescales; and A Site Verification Report detailing the actions taken and conclusions at each stage of the remediation works, including substantiating evidence, shall be submitted to and approved in writing by the Local Planning Authority prior to the development

being brought into use.

Reason. To secure the satisfactory development of the site in terms of human health, controlled waters and the wider environment and pursuant to National Planning Policy Framework Section 15 - Conserving and enhancing the natural environment.

- 3 Prior to first occupation of the development hereby approved, a sprinkler/misting system to meet the requirements of BS 9251:2014 or other subsequent standard that meets the requirements of Greater Manchester Fire and Rescue Service and deemed suitable to overcome the site's emergency access deficiencies and a fire detection and alarm system shall be installed in each of the dwellings hereby approved and shall thereafter be maintained at all times.

Reason. In the interests of fire safety and to ensure the safe and satisfactory development of the site and for its future occupiers pursuant to Bury Unitary Development Plan Policies H1/2 - Further Housing Development, H2/2 - The Layout of New Residential Development and EN1/2 - Townscape and Built Design

- 4 The external finishing materials for the proposal hereby approved shall match those of the existing building.

Reason. In the interests of visual amenity and to ensure a satisfactory development pursuant to Policy EN1/2 - Townscape and Built Design of Bury Unitary Development Plan.

The following policies of the Bury Unitary Development Plan, National and Regional Government were considered relevant:

H1/2	H1/2 - Further Housing Development
H2/4	H2/4 - Conversions
EN1/1	EN1/1 - Visual Amenity
EN1/2	EN1/2 - Townscape and Built Design
EN6/3	EN6/3 - Features of Ecological Value
EN7	EN7 - Pollution Control
EN7/5	EN7/5 - Waste Water Management
RT3/3	RT3/3 - Access to the Countryside
RT3/4	RT3/4 - Recreational Routes
HT4	HT4 - New Development
HT2/4	HT2/4 - Car Parking and New Development
HT6/2	HT6/2 - Pedestrian/Vehicular Conflict
NPPF	National Planning Policy Framework
NPPG	National Planning Policy Guide

This decision relates only to the Town and Country Planning Acts and does not include any consent or approval under any other enactment or under the Building Regulations. Any other consent or approval which is necessary must be obtained from the appropriate authority.

Applicant Plan Numbers:

NOTES TO APPLICANT

1. The applicant must be made aware of the need to safeguard people using public rights of way and that no public rights of way are damaged, widths altered, gates erected across their width (unless authorised by Bury Council the Highway Authority) or obstructed by any other means either during or as a result of development. The applicant must ensure that no changes to land levels/surface water runoff affects a public right of way. If a temporary obstruction of public rights of way is unavoidable,

no development must take place until a temporary closure order has been made by Bury Council and a suitable temporary alternative route(s) made available.

Signed:

A handwritten signature in black ink, appearing to read 'Paul Harris', written in a cursive style.

3 of 3

.....
On behalf of the Council

Date of Decision: 20/07/2023