

The technical spec and application form state that the heat pump could be over 42dB, as stated heat pump guidance. The level could be 45db at neighbours window. Their report states fail. Without some mitigation of the heat pump from noise then a decline of the application.

thanks

Unit Manager, Commercial Team
Bury Council | Department for Operations | Public Protection
3 Knowsley Place | Duke Street | Bury | BL9 0EJ