

Bury Metropolitan Borough Council
Town Hall
Knowsley Street
Bury
Lancashire
BL9 0SW

Our ref: SO/2021/121416/01-L01
Your ref: 67243
Date: 18 August 2021

Dear Sir/Madam

**ERECTION OF 8 DWELLINGS, AND NEW / IMPROVED FORMAL AND INFORMAL
COMMUNITY OPEN SPACE / PLAY SPACE, REPLACEMENT / IMPROVED
FOOTPATH CONNECTIONS AND WIDER GREENSPACE ENHANCEMENTS LAND
OFF BROWNHILLS CLOSE / BURY ROAD, TOTTINGTON**

Thank you for referring the above application to the Environment Agency. We have no objection in principle to the proposed development.

Environment Agency position

We have reviewed the report - Phase 1 Preliminary Risk Assessment for the proposed development of land off Brownhills Close, Tottington for residential units dated June 2021 and we would wish to make the following comments.

The following planning condition should be included as set out below. Without this condition, the proposed development on this site poses an unacceptable risk to the environment.

Condition

No development approved by this planning permission shall take place until a remediation strategy that includes the following components to deal with the risks associated with contamination of the site shall each be submitted to and approved, in writing, by the local planning authority:

1. A site investigation scheme, based on the information already submitted, to provide information for a detailed assessment of the risk to all receptors that may be affected, including those off site.

Environment Agency
Richard Fairclough House Knutsford Road, Warrington, WA4 1HT.
Customer services line: 03708 506 506
www.gov.uk/environment-agency

Cont/d..

2. The results of the site investigation and the detailed risk assessment referred to in (1) and, based on these, an options appraisal and remediation strategy giving full details of the remediation measures required and how they are to be undertaken.
3. A verification plan providing details of the data that will be collected in order to demonstrate that the works set out in the remediation strategy in (2) are complete and identifying any requirements for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action.

Any changes to these components require the express written consent of the local planning authority. The scheme shall be implemented as approved.

Reason

For the ongoing protection of the Water Environment from risks arising from land contamination.

Condition

No infiltration of surface water drainage into the ground where adverse concentrations of contamination are known or suspected to be present is permitted other than with the express written consent of the local planning authority, which may be given for those parts of the site where it has been demonstrated that there is no resultant unacceptable risk to controlled waters. The development shall be carried out in accordance with the approval details.

Reason

For the future protection of the Water Environment from risks arising from land contamination.

Condition

Piling or any other foundation designs using penetrative methods shall not be permitted other than with the express written consent of the local planning authority, which may be given for those parts of the site where it has been demonstrated that there is no resultant unacceptable risk to groundwater. The development shall be carried out in accordance with the approved details.

Reasons

For the future protection of the Water Environment from risks arising from land contamination.

Condition

Prior to any part of the permitted development being occupied, a verification report demonstrating the completion of works set out in the approved remediation strategy and the effectiveness of the remediation shall be submitted to, and approved in writing, by the local planning authority. The report shall include results of sampling and monitoring carried out in accordance with the approved verification plan to demonstrate that the site remediation criteria have been met.

Reasons

For the ongoing protection of the Water Environment from risks arising from land contamination.

Advice to applicant

Model Procedures and good practice

Due to the former land use(s), soil and /or groundwater contamination may exist at the site and the associated risks to controlled waters should be addressed by:

We recommend that developers should:

- Follow the risk management framework provided in Guidance on Land contamination risk management (LCRM), when dealing with land affected by contamination
- Refer to our [Guiding principles for land contamination](#) for the type of information that we require in order to assess risks to controlled waters from the site - the local authority can advise on risk to other receptors, such as human health
- Consider using the [National Quality Mark Scheme for Land Contamination Management](#) which involves the use of competent persons to ensure that land contamination risks are appropriately managed
- Refer to the [contaminated land](#) pages on gov.uk for more information

All investigations of land potentially affected by contamination should be carried out by or under the direction of a suitably qualified competent person and in accordance with BS 10175 (2001) Code of practice for the investigation of potentially contaminated sites. The competent person would normally be expected to be chartered member of an appropriate body (such as the Institution of Civil Engineers, Geological Society of London, Royal Institution of Chartered Surveyors, Institution of Environmental Management) and also have relevant experience of investigating contaminated sites. The Specialist in Land Condition (SiLC) qualification administered by the Institution of Environmental Management provides an accredited status for those responsible for signing off LCR's. For further information see - www.silc.org.uk
Where the remediation / redevelopment of the site will involve waste management issues we offer the following advice:

Waste on-site

The CL:AIRE Definition of Waste: Development Industry Code of Practice (version 2) provides operators with a framework for determining whether or not excavated material arising from site during remediation and/or land development works is waste or has ceased to be waste. Under the Code of Practice:

- excavated materials that are recovered via a treatment operation can be reused on-site providing they are treated to a standard such that they are fit for purpose and unlikely to cause pollution
- treated materials can be transferred between sites as part of a hub and cluster project
- some naturally occurring clean material can be transferred directly between sites

Developers should ensure that all contaminated materials are adequately characterised both chemically and physically, and that the permitting status of any proposed on-site operations are clear. If in doubt, the Environment Agency should be contacted for advice at an early stage to avoid any delays.

We recommend that developers should refer to:

- the [position statement](#) on the Definition of Waste: Development Industry Code of Practice

- The [waste management](#) page on GOV.UK

Waste to be taken off-site

Contaminated soil that is (or must be) disposed of is waste. Therefore, its handling, transport, treatment and disposal are subject to waste management legislation, which includes:

- Duty of Care Regulations 1991
- Hazardous Waste (England and Wales) Regulations 2005
- Environmental Permitting (England and Wales) Regulations 2016
- The Waste (England and Wales) Regulations 2011

Developers should ensure that all contaminated materials are adequately characterised both chemically and physically in line with British Standard BS EN 14899:2005 'Characterization of Waste - Sampling of Waste Materials - Framework for the Preparation and Application of a Sampling Plan' and that the permitting status of any proposed treatment or disposal activity is clear. If in doubt, the Environment Agency should be contacted for advice at an early stage to avoid any delays.

If the total quantity of hazardous waste material produced or taken off-site is 500kg or greater in any 12 month period, the developer will need to register with us as a hazardous waste producer. Refer to the [hazardous waste](#) pages on GOV.UK for more information.

Introduction of SUDS

Approved Document Part H of the Building Regulations 2000 establishes a hierarchy for surface water disposal, which encourages a SUDS approach. Under Approved Document Part H the first option for surface water disposal should be the use of SUDS, which encourage infiltration such as soakaways or infiltration trenches. In all cases, it should be established that these options are feasible, can be adopted and properly maintained and would not lead to any other environmental problems. For example, using soakaways or other infiltration methods on contaminated land carries groundwater pollution risks and may not work in areas with a high water table. Where the intention is to dispose to soakaway, these should be shown to work through an appropriate assessment carried out under Building Research Establishment (BRE) Digest 365.

Piling and Penetrative ground improvement methods

Piling or any other foundation designs using penetrative methods can result in risks to potable supplies from, for example, pollution / turbidity, risk of mobilising contamination, drilling through different aquifers and creating preferential pathways.

Thus it should be demonstrated that any proposed piling will not result in contamination of groundwater.

Dewatering

Dewatering is the removal/abstraction of water (predominantly, but not confined to, groundwater) in order to locally lower water levels near the excavation. This can allow operations to take place, such as mining, quarrying, building, engineering works or other operations, whether underground or on the surface. Any dewatering activities on-site could have an impact upon local wells, water supplies and/or nearby watercourses and environmental interests. This activity was previously exempt from requiring an abstraction licence. Since 1 January 2018, most cases of new planned dewatering operations above 20 cubic metres a day will require a water abstraction licence from us prior to the commencement of dewatering activities at the site. More information is available on gov.uk:

<https://www.gov.uk/guidance/water-management-apply-for-a-water-abstraction-or-impoundment-licence#apply-for-a-licence-for-a-previously-exempt-abstraction>.

Regulatory position statements

If dewatering and discharging into surface water is required during development, the following Regulatory Position Statement will apply: 'Temporary dewatering from excavations to surface water.'

<https://www.gov.uk/government/publications/temporary-dewatering-from-excavations-to-surface-water>

Seeking additional advice and support

As there may be challenging technical issues regarding this development, we have introduced a chargeable scheme whereby detailed technical advice and guidance can be sought from a dedicated technical officer in the groundwater and contaminated land team for the duration of the project.

Should you wish us to review any technical documents or want further advice to address the environmental issues raised/meet the requirements of the conditions recommended, we may do this as part of our charged for planning advice service.

Further engagement will provide you with the opportunity to discuss and gain our views on potential options with us. It should also result in a better quality and more environmentally sensitive development.

We currently charge £100 per hour, plus VAT. We will provide you with an estimated cost for any further discussions or review of documents. The terms and conditions of our charged for service are available

<https://www.gov.uk/government/publications/planning-advice-environment-agency-standard-terms-and-conditions>

If you would like more information on our planning advice service, including a cost estimate, please contact us at SPPlanning.RFH@environment-agency.gov.uk

Please send me a copy of the decision notice and forward a copy of this letter to the applicant.

Yours faithfully

Mrs SYLVIA WHITTINGHAM
Planning Advisor

Direct dial 0203 0251059

Direct e-mail sylvia.whittingham@environment-agency.gov.uk