



Section A-A



Internally Illuminated Sign

WILLIAM HILL FASCIA SIZE GUIDE			
Fascia Height = Y	Log H Cap Height = X (45% of the Fascia HT)	Aluminium Thickness	Letter Span = Z
Up to 1000mm	450mm	3mm	2945mm
Up to 900mm	405mm	3mm	2694mm
Up to 750mm	338mm	2mm	2248mm
Up to 600mm	270mm	2mm	1795mm

INTERNALLY ILLUMINATED SIGN

Fret Cut Aluminium Fascia Powder Coated RAL 5013 With Push Through to Fit 5mm Thick Yellow 229 & Opal 050 Perspex

GE Tetra MiniMAX G3 LED's Mounted To 3mm ACM Tray - Illumination does not exceed 600cd/m2

YELLOW	229
BLUE	RAL 5013
WHITE	OPAL 050

Internally Illuminated Projecting Sign

Aluminium frame and bracket powder coated Blue to RAL 5013

Polycarbonate face panels with self adhesive vinyl display. Internally Illuminated via 8no GE Edgestrip LED Modules Illumination does not exceed 600cd/m2

External Signage Details
1:25 @ A3



IMPORTANT NOTICE

This Drawing remains the copyright of William Hill PLC and shall not be altered or copied in whole or in part without their prior written consent

ASBESTOS:

June 2022

In view of the age of the property, a hidden presence of asbestos is possible. Prior to commencement of work, an R & D Survey will be carried out in all concealed areas

Before commencement of the works William Hill will instruct a specialist to carry out an R & D asbestos survey, the result of which are to be included within the Contractors Health and Safety Plan.

Air Conditioning Condenser Units

Positioning of the A/C Condenser units have been shown as instructed by the PM's and ratified by Development. Positioning must have Landlords approval, and all relevant planning permissions. Access to the units must be provided with guard rails, steel cages, enclosures and any screening provided where necessary

Installation & servicing of any A/C, SIS or Aerial Equipment should be done under strict H&S conditions, paying particular attention to the ACR (CP) 006: 2009 - Practical Methods Of providing Edge Projection For Working On Roof and HSG33 guidelines 'Health & Safety in Roof Work' Work is only to be under taken by a competent person(s) as per the ACR 'Black Book'. Edge protection & anchor points should be installed as required if not already present (present ones should only be used if tested & in date)

Access to flat roof/installed ac units etc should be done via on site access ladders if available or suitable portable ladders to EN131 or class one industrial 90kg-150kg loadings.

PROPOSED

GROSS UNIT AREA	700	SQFT
GROSS CUSTOMER AREA	524	SQFT
NET CUSTOMER AREA	432	SQFT
NEWSPAPER DISPLAY AREA	LFT	

DO NOT SCALE OFF THIS DRAWING EXCEPT FOR PLANNING PURPOSES

ORGANIZATION LTD

Site. 8 CHURCH STREET WEST
RADCLIFFE-ON-TRENT
M26 2SQ
RADCLIFFE

Description.
PROPOSED SIGNAGE DETAILS

Date. 02/09/2022	Scale. 1:25@A3
Drawn. AW	PM. SB
Drawing Number. FINAL/SIGNAGE/501	Revision.