

G and T Pointing and Restoration

Mortar Analysis Email Correspondence

29 Summerseat Lane | 16 August 2026

Purpose: Summary of the email exchange between Bradley Hamilton and Dr Mark Womersley regarding the mortar analysis and suitability of the proposed replacement mortar mix.

Mark Womersley → Bradley Hamilton

Dr Mark Womersley — Managing Director, M. Womersleys Ltd

Dear Bradley,

Please find attached the mortar analysis results for 29 Summerseat Lane.

Best regards

Mark

Email included the mortar analysis report as an attachment.

Bradley Hamilton → Dr Mark Womersley

Bradley Hamilton — Managing Director, G and T Pointing and Restoration

Thank you so much for this Mark,

I spoke with Josh when I brought it in; he was thinking roughly my 3:1 mix with each of the sands.

Is there anything I need to do with this one differently? I'm just not sure what I'm looking for on the attachment.

Thanks so much again.

Bradley asked for confirmation that the proposed 3:1 mix using the selected sands was suitable.

Dr Mark Womersley → Bradley Hamilton

Dr Mark Womersley — Managing Director, M. Womersleys Ltd

Dear Bradley,

It would be impossible to match the original, as the lime is now much too pure. Your suggested mix is appropriate.

Best regards

Mark

This email confirmed that the original analysed mortar could not be replicated exactly and that Bradley's suggested replacement mix was appropriate.