

BURY COUNCIL
DEPARTMENT OF OPERATIONS

REF NO: 23/162

FROM: Head of Engineering

TO: Head of Development Management

Planning Application No: 69706

Location: The Gatehouse, Woodhill Road, Bury, BL8 1BN

Development: Partial demolition and replacement of 1 No. dwelling

RECOMMENDATION

I recommend that any planning permission given shall include the following conditions:

1. No development shall commence unless and until a 'Construction Traffic Management Plan' (CTMP), has been submitted to and agreed in writing with the Local Planning Authority and shall confirm/provide the following:
 - Photographic dilapidation survey of the footways and carriageways abutting the site in the event that subsequent remedial works are required following demolition works/construction of the development and as a result of statutory undertakers connections to the site;
 - Access point and route for demolition/construction traffic from the adopted highway;
 - Hours of operation and number of vehicle movements;
 - A scheme of appropriate warning/construction traffic speed signage in the vicinity of the site and its access;
 - Arrangements for the turning and manoeuvring of vehicles within the curtilage of the site, including any requisite phasing of the development to accommodate this;
 - Parking on site of operatives' and demolition/construction vehicles together with storage on site of demolition/construction materials, including any requisite phasing of the development to accommodate this;
 - If proposed, site hoarding/gate positions clear of the existing shared access, including the provision, where necessary, of temporary pedestrian facilities/protection measures;
 - Measures to ensure that all mud and other loose materials are not carried on the wheels and chassis of any vehicles leaving the site and measures to minimise dust nuisance caused by the operations.

The approved plan shall be adhered to throughout the demolition and construction periods and the measures shall be retained and facilities used for the intended purpose for the duration of the both periods.

Cont/.....

The areas identified shall not be used for any other purposes other than the turning/parking of vehicles and storage of demolition/construction materials. All highway remedial works identified as a result of the dilapidation survey shall be implemented to the written satisfaction of the Local Planning Authority prior to the development hereby approved being occupied.

2. The enlarged hardstanding indicated on approved plan reference 002 Revision D shall incorporate hardstanding materials and/or a scheme of surface water drainage works to ensure that surface water will not be discharged onto the adjacent adopted highway and be implemented to the satisfaction of the Local Planning Authority.
3. The turning facilities indicated on approved plan reference 002 Revision D shall be provided before the development is first occupied and the areas used for the manoeuvring of vehicles shall subsequently be maintained free of obstruction at all times. (HY14 Amended)
4. The car parking indicated on approved plan reference 002 Revision D shall be surfaced and made available for use to the written satisfaction of the Local Planning Authority prior to the development hereby approved being occupied and thereafter maintained at all times. (CAR1 Amended)

Reasons

1. To maintain the integrity of the adopted highway, mitigate the impact of the demolition/construction traffic generated by the proposed development on the adjacent residential streets, ensure adequate off street car parking provision and materials storage arrangements for the duration of the demolition and construction periods and ensure that the adopted highways are kept free of deposited material from the demolition/ground works operations, in the interests of highway safety.
2. To ensure good highway design and maintain the integrity of the adopted highway, in the interests of highway safety.
3. To minimise the standing and turning movements of vehicles on the highway in the interests of road safety and ensure that the turning facilities are not obstructed by parked vehicles.
4. To ensure adequate off street car parking provision in the interests of road safety.

Comments and Observations

The applicant's attention is drawn to the need to consult the Department for Operations regarding the specification for and implementation of any required highway remedial works. The cost of the works will be the responsibility of the applicant. (N011 Amended)

Cont/.....

Date: 01 June 2023

Signed: **A Southgate**
(pp) Head of Engineering

HIGHWAYS ASPECTS ONLY