

I just have a couple of comments on this application:

- Space for bins : as there will be 23 occupants in sole occupancies there will need to be at least 10 1100 litre bins on site. I have attached the dimensions so that the applicant can see the space required.
- Access for refuse vehicle: We have had a few access issues here in the past with cars parking near to the corner of Back Brierley Street South. Also if possible our vehicle would like to reverse as close to the bins as possible so if the gate could be wide enough to allow this then that would be appreciated.

Kind Regards

Cameron Goggins
Waste Technical Officer
Department of Operations