

**72383 – Smithie Garage, Spring Street, Ramsbottom.**

**Conversion of former garage into 1 No. two storey dwelling.**

No objection in principle.

Physical samples of the natural stone and slate to be used, including natural stone window headers, cills and jambs shall be submitted for approval before the commencement of any works.

The facing stone sample should take the form a panel on site 1m square and be of a rock face finish to match the existing and Nos 8 and 10 Spring Street.

The stone jambs, cills and headers shall be of ashlar finish natural stone.

Conservation Officer

3/2/26