

EH comments

The noise assessment has identified mitigation measures:

- The minimum standard, tested in accordance with ISO 10140-2:2010 (double skinned external; brick, plaster Rw 55-58dB)for all non glazed elements: facade, walls and roof the (noise report section 7.3)
- including an attenuation level for glazed building elements (noise report section 7.4)
 - Bedrooms minimum single figure weighted sound reduction of 38dB
 - Living rooms minimum single figure weighted sound reduction of 34dB
 - including acoustic ventilation trickle vents and
- secondary double glazing (noise report section 7.5 -7.8)

The above is in the proposed plan, however needs to be a condition to ensure is carried out on refurbishment.

Many thanks

Rob Hall

Unit Manager, Environmental Health Commercial Team
Bury Council | Public Protection Service
3 Knowsley Place | Duke Street | Bury | BL9 0EJ