

JD Sports Campus:	Date: 15/10/2025		
	Designed by: RM	Checked by: JH	Approved By: PV
Report Details: Type: Junctions Summary Storm Phase: Phase	Kennedy Redford: 20 Market Street Altrincham WA14 1PF		



FEH: 2 years: Increase Rainfall (%): +0: Critical Storm Per Item: Rank By: Max. Depth

Junction	Storm Event	Cover Level (m)	Invert Level (m)	Max. Level (m)	Max. Depth (m)	Max. Inflow (L/s)	Max. Resident Volume (m³)	Max. Flooded Volume (m³)	Max. Outflow (L/s)	Total Discharge Volume (m³)	Status
Manhole (18)	FEH: 2 years: +0 %: 60 mins: Winter	88.395	87.000	87.034	0.034	3.0	0.039	0.000	3.0	6.321	OK
Manhole (17)	FEH: 2 years: +0 %: 60 mins: Winter	88.447	86.730	86.781	0.051	6.1	0.058	0.000	6.1	13.477	OK
Manhole (16)	FEH: 2 years: +0 %: 240 mins: Winter	88.479	86.499	86.681	0.182	8.2	0.206	0.000	8.1	56.411	OK
Manhole (15)	FEH: 2 years: +0 %: 240 mins: Winter	88.292	86.180	86.680	0.500	16.6	0.566	0.000	7.7	140.331	Surcharged
Manhole (14)	FEH: 2 years: +0 %: 240 mins: Winter	88.521	86.322	86.681	0.359	8.8	0.406	0.000	8.6	61.975	Surcharged
Manhole (13)	FEH: 2 years: +0 %: 240 mins: Winter	88.429	86.282	86.680	0.399	12.4	0.451	0.000	16.6	149.312	Surcharged
Manhole (12)	FEH: 2 years: +0 %: 240 mins: Winter	88.596	86.359	86.681	0.322	7.7	0.364	0.000	7.5	90.520	Surcharged
Manhole (11)	FEH: 2 years: +0 %: 15 mins: Winter	88.808	86.800	86.826	0.026	5.3	0.004	0.000	5.2	2.432	OK
Manhole (10)	FEH: 2 years: +0 %: 240 mins: Winter	88.796	86.402	86.681	0.279	10.7	0.315	0.000	10.4	61.198	Surcharged
Manhole (9)	FEH: 2 years: +0 %: 15 mins: Winter	88.796	86.559	86.699	0.141	31.2	0.159	0.000	29.1	16.047	OK
Manhole (8)	FEH: 2 years: +0 %: 15 mins: Winter	88.858	86.758	86.879	0.121	25.1	0.137	0.000	23.7	12.255	OK
Manhole (7)	FEH: 2 years: +0 %: 15 mins: Winter	88.600	86.930	87.013	0.083	13.9	0.094	0.000	13.5	6.425	OK
Manhole (6)	FEH: 2 years: +0 %: 240 mins: Winter	88.480	87.327	87.349	0.022	1.0	0.025	0.000	1.0	5.262	OK
Manhole (5)	FEH: 2 years: +0 %: 15 mins: Winter	88.571	87.062	87.102	0.040	4.6	0.045	0.000	3.5	2.164	OK
Manhole (4)	FEH: 2 years: +0 %: 360 mins: Winter	88.295	87.382	87.395	0.013	0.4	0.015	0.000	0.4	2.503	OK
Manhole (20)	FEH: 2 years: +0 %: 120 mins: Summer	88.300	86.000	86.057	0.057	7.9	0.000	0.000	8.0	75.069	OK
Manhole (21)	FEH: 2 years: +0 %: 240 mins: Winter	88.570	86.570	86.681	0.111	3.1	0.018	0.000	3.1	18.110	OK

JD Sports Campus:	Date: 15/10/2025		
	Designed by: RM	Checked by: JH	Approved By: PV
Report Details: Type: Junctions Summary Storm Phase: Phase	Kennedy Redford: 20 Market Street Altrincham WA14 1PF		



FEH: 30 years: Increase Rainfall (%): +35: Critical Storm Per Item: Rank By: Max. Depth

Junction	Storm Event	Cover Level (m)	Invert Level (m)	Max. Level (m)	Max. Depth (m)	Max. Inflow (L/s)	Max. Resident Volume (m³)	Max. Flooded Volume (m³)	Max. Outflow (L/s)	Total Discharge Volume (m³)	Status
Manhole (18)	FEH: 30 years: +35 %: 360 mins: Winter	88.395	87.000	87.464	0.464	3.8	0.525	0.000	3.8	33.618	Surcharged
Manhole (17)	FEH: 30 years: +35 %: 360 mins: Winter	88.447	86.730	87.463	0.734	8.9	0.830	0.000	8.5	78.339	Surcharged
Manhole (16)	FEH: 30 years: +35 %: 360 mins: Winter	88.479	86.499	87.465	0.965	20.8	1.092	0.000	20.5	176.770	Surcharged
Manhole (15)	FEH: 30 years: +35 %: 360 mins: Winter	88.292	86.180	87.464	1.284	7.9	1.452	0.000	7.7	265.420	Surcharged
Manhole (14)	FEH: 30 years: +35 %: 360 mins: Winter	88.521	86.322	87.470	1.148	21.7	1.298	0.000	21.6	180.709	Surcharged
Manhole (13)	FEH: 30 years: +35 %: 360 mins: Winter	88.429	86.282	87.462	1.181	23.1	1.335	0.000	7.7	347.352	Surcharged
Manhole (12)	FEH: 30 years: +35 %: 360 mins: Winter	88.596	86.359	87.466	1.107	17.4	1.252	0.000	8.0	230.208	Surcharged
Manhole (11)	FEH: 30 years: +35 %: 360 mins: Winter	88.800	86.800	87.466	0.666	2.3	0.106	0.000	2.2	19.457	Surcharged
Manhole (10)	FEH: 30 years: +35 %: 360 mins: Winter	88.796	86.402	87.466	1.065	18.7	1.204	0.000	18.5	164.367	Surcharged
Manhole (9)	FEH: 30 years: +35 %: 15 mins: Winter	88.796	86.559	87.468	0.910	80.3	1.029	0.000	72.9	46.389	Surcharged
Manhole (8)	FEH: 30 years: +35 %: 15 mins: Winter	88.858	86.758	87.793	1.035	66.8	1.171	0.000	56.7	36.183	Surcharged
Manhole (7)	FEH: 30 years: +35 %: 15 mins: Winter	88.600	86.930	87.881	0.951	41.0	1.075	0.000	30.4	18.941	Surcharged
Manhole (6)	FEH: 30 years: +35 %: 360 mins: Winter	88.480	87.327	87.464	0.137	2.4	0.155	0.000	2.4	19.131	OK
Manhole (5)	FEH: 30 years: +35 %: 360 mins: Winter	88.571	87.062	87.464	0.402	6.2	0.455	0.000	6.2	48.099	Surcharged
Manhole (4)	FEH: 30 years: +35 %: 360 mins: Winter	88.295	87.382	87.464	0.082	1.1	0.093	0.000	1.1	8.512	OK
Manhole (20)	FEH: 30 years: +35 %: 960 mins: Summer	88.300	86.000	86.056	0.056	7.9	0.000	0.000	7.9	518.678	OK
Manhole (21)	FEH: 30 years: +35 %: 360 mins: Winter	88.570	86.570	87.466	0.896	5.8	0.143	0.000	5.7	49.541	Surcharged

JD Sports Campus:	Date: 15/10/2025		
	Designed by: RM	Checked by: JH	Approved By: PV
Report Details: Type: Junctions Summary Storm Phase: Phase	Kennedy Redford: 20 Market Street Altrincham WA14 1PF		



FEH: 100 years: Increase Rainfall (%): +40: Critical Storm Per Item: Rank By: Max. Depth

Junction	Storm Event	Cover Level (m)	Invert Level (m)	Max. Level (m)	Max. Depth (m)	Max. Inflow (L/s)	Max. Resident Volume (m³)	Max. Flooded Volume (m³)	Max. Outflow (L/s)	Total Discharge Volume (m³)	Status
Manhole (18)	FEH: 100 years: +40 %: 480 mins: Winter	88.395	87.000	88.114	1.115	10.1	1.261	0.000	3.7	68.204	Flood Risk
Manhole (17)	FEH: 100 years: +40 %: 480 mins: Winter	88.447	86.730	88.114	1.384	14.9	1.566	0.000	9.3	135.376	Surcharged
Manhole (16)	FEH: 100 years: +40 %: 240 mins: Winter	88.479	86.499	88.114	1.615	34.3	1.827	0.000	34.0	229.919	Surcharged
Manhole (15)	FEH: 100 years: +40 %: 240 mins: Winter	88.292	86.180	88.135	1.955	10.7	2.211	0.000	9.0	208.976	Flood Risk
Manhole (14)	FEH: 100 years: +40 %: 240 mins: Winter	88.521	86.322	88.117	1.795	36.0	2.030	0.000	35.7	220.631	Surcharged
Manhole (13)	FEH: 100 years: +40 %: 240 mins: Winter	88.429	86.289	88.118	1.837	38.2	2.077	0.000	10.6	328.569	Surcharged
Manhole (12)	FEH: 100 years: +40 %: 240 mins: Winter	88.596	86.359	88.126	1.767	31.7	1.999	0.000	17.8	217.665	Surcharged
Manhole (11)	FEH: 100 years: +40 %: 240 mins: Winter	88.808	86.800	88.134	1.334	6.8	0.212	0.000	4.5	24.660	Surcharged
Manhole (10)	FEH: 100 years: +40 %: 240 mins: Winter	88.796	86.402	88.126	1.724	33.3	1.950	0.000	32.9	190.209	Surcharged
Manhole (9)	FEH: 100 years: +40 %: 240 mins: Winter	88.796	86.559	88.130	1.571	26.1	1.777	0.000	25.7	149.143	Surcharged
Manhole (8)	FEH: 100 years: +40 %: 15 mins: Winter	88.858	86.758	88.438	1.680	90.3	1.900	0.000	70.3	47.840	Surcharged
Manhole (7)	FEH: 100 years: +40 %: 15 mins: Winter	88.600	86.930	88.601	1.670	53.5	1.913	0.024	46.2	24.839	Flood
Manhole (6)	FEH: 100 years: +40 %: 480 mins: Winter	88.480	87.327	88.108	0.781	5.7	0.883	0.000	5.7	59.718	Surcharged
Manhole (5)	FEH: 100 years: +40 %: 480 mins: Winter	88.571	87.062	88.109	1.048	7.9	1.185	0.000	7.9	110.719	Surcharged
Manhole (4)	FEH: 100 years: +40 %: 480 mins: Winter	88.295	87.382	88.109	0.727	2.3	0.822	0.000	2.6	25.801	Flood Risk
Manhole (20)	FEH: 100 years: +40 %: 960 mins: Winter	88.300	86.000	86.060	0.060	9.0	0.000	0.000	9.0	726.224	OK
Manhole (21)	FEH: 100 years: +40 %: 360 mins: Winter	88.570	86.570	88.126	1.556	7.5	0.247	0.000	7.3	63.649	Surcharged

JD Sports Campus:	Date: 15/10/2025		
	Designed by: RM	Checked by: JH	Approved By: PV
Report Details: Type: Stormwater Controls Summary Storm Phase: Phase	Kennedy Redford: 20 Market Street Altrincham WA14 1PF		





FEH: 2 years: Increase Rainfall (%): +0: Critical Storm Per Item: Rank By: Max.
Avg. Depth

JD Sports Campus:		Date: 15/10/2025		
		Designed by: RM	Checked by: JH	Approved By: PV
Report Details: Type: Stormwater Controls Summary Storm Phase: Phase		Kennedy Redford: 20 Market Street Altrincham WA14 1PF		



Stormwater Control	Storm Event	Max. US Level (m)	Max. DS Level (m)	Max. US Depth (m)	Max. DS Depth (m)	Max. Inflow (L/s)	Max. Residual Volume (m³)	Max. Flooded Volume (m³)	Total Lost Volume (m³)	Max. Outflow (L/s)	Total Discharge Volume (m³)	Percentage Available (%)	Status
Porous Paving (5)	FEH: 2 years: +0 %: 60 mins: Winter	88.089	88.059	0.025	0.009	0.8	0.425	0.000	0.000	0.7	1.101	93.348	OK
Porous Paving (6)	FEH: 2 years: +0 %: 960 mins: Winter	88.085	88.055	0.020	0.005	0.2	0.357	0.000	0.000	0.3	5.159	94.863	OK
Porous Paving (7)	FEH: 2 years: +0 %: 1440 mins: Winter	88.085	88.055	0.020	0.005	0.2	0.346	0.000	0.000	0.3	6.327	95.033	OK
Porous Paving (8)	FEH: 2 years: +0 %: 30 mins: Winter	88.089	88.057	0.025	0.007	1.0	0.403	0.000	0.000	0.7	0.780	93.687	OK
Bioretention	FEH: 2 years: +0 %: 960 mins: Winter	88.199	88.085	0.314	0.235	0.4	6.241	0.000	0.000	0.2	3.515	80.223	OK
Bioretention (1)	FEH: 2 years: +0 %: 240 mins: Winter	88.286	87.854	0.311	0.004	0.7	3.774	0.000	0.000	0.1	1.149	86.599	OK
Bioretention (2)	FEH: 2 years: +0 %: 360 mins: Winter	88.159	87.811	0.324	0.011	0.4	2.527	0.000	0.000	0.3	1.854	84.951	OK
Bioretention (3)	FEH: 2 years: +0 %: 240 mins: Winter	88.140	87.816	0.323	0.016	1.1	3.970	0.000	0.000	0.8	3.709	82.529	OK
Porous Paving (11)	FEH: 2 years: +0 %: 30 mins: Winter	88.737	88.221	0.024	0.011	0.9	0.379	0.000	0.000	0.9	0.811	93.297	OK
Porous Paving (12)	FEH: 2 years: +0 %: 30 mins: Winter	88.446	88.187	0.013	0.009	0.7	0.188	0.000	0.000	0.6	0.613	95.553	OK
Porous Paving (13)	FEH: 2 years: +0 %: 30 mins: Winter	88.446	88.188	0.013	0.010	0.7	0.190	0.000	0.000	0.6	0.613	95.511	OK
Porous Paving (14)	FEH: 2 years: +0 %: 30 mins: Winter	88.413	88.187	0.012	0.009	0.6	0.146	0.000	0.000	0.5	0.512	95.875	OK
Porous Paving (15)	FEH: 2 years: +0 %: 30 mins: Winter	88.447	88.187	0.013	0.009	0.7	0.188	0.000	0.000	0.6	0.611	95.566	OK
Porous Paving (16)	FEH: 2 years: +0 %: 15 mins: Winter	88.426	88.164	0.011	0.007	0.6	0.067	0.000	0.000	0.4	0.243	97.087	OK
Porous Paving (17)	FEH: 2 years: +0 %: 15 mins: Winter	88.426	88.163	0.011	0.006	0.6	0.064	0.000	0.000	0.4	0.243	97.207	OK
Porous Paving	FEH: 2 years: +0 %: 60 mins: Winter	88.213	88.103	0.033	0.020	4.2	2.954	0.000	0.000	2.9	5.832	86.308	OK
Porous Paving (1)	FEH: 2 years: +0 %: 60 mins: Winter	88.143	88.035	0.025	0.013	2.4	1.930	0.000	0.000	1.4	3.268	90.250	OK
Porous Paving (2)	FEH: 2 years: +0 %: 60 mins: Winter	88.082	87.978	0.025	0.017	2.4	1.973	0.000	0.000	1.4	3.234	90.036	OK
Porous Paving (3)	FEH: 2 years: +0 %: 60 mins: Winter	88.034	87.915	0.038	0.015	2.9	2.457	0.000	0.000	1.8	4.014	87.601	OK
Cellular Storage	FEH: 2 years: +0 %: 240 mins: Winter	86.681	86.681	0.301	0.301	16.0	80.010	0.000	0.000	7.7	82.349	75.013	OK

JD Sports Campus:	Date: 15/10/2025		
	Designed by: RM	Checked by: JH	Approved By: PV
Report Details: Type: Stormwater Controls Summary Storm Phase: Phase	Kennedy Redford: 20 Market Street Altrincham WA14 1PF		





FEH: 30 years: Increase Rainfall (%): +35: Critical Storm Per Item: Rank By: Max.
 Avg. Depth

Stormwater Control	Storm Event	Max. US Level (m)	Max. DS Level (m)	Max. US Depth (m)	Max. DS Depth (m)	Max. Inflow (L/s)	Max. Residual Volume (m³)	Max. Flooded Volume (m³)	Total Lost Volume (m³)	Max. Outflow (L/s)	Total Discharge Volume (m³)	Percentage Available (%)	Status
Porous Paving (5)	FEH: 30 years: +35 %: 30 mins: Winter	88.114	88.068	0.050	0.018	3.1	0.810	0.000	0.000	2.8	2.638	87.315	OK
Porous Paving (6)	FEH: 30 years: +35 %: 120 mins: Winter	88.117	88.062	0.052	0.012	1.8	0.816	0.000	0.000	1.6	7.245	88.277	OK
Porous Paving (7)	FEH: 30 years: +35 %: 120 mins: Winter	88.116	88.061	0.051	0.011	1.8	0.807	0.000	0.000	1.6	7.218	88.397	OK
Porous Paving (8)	FEH: 30 years: +35 %: 30 mins: Winter	88.114	88.064	0.049	0.014	3.1	0.784	0.000	0.000	2.8	2.647	87.722	OK
Bioretention	FEH: 30 years: +35 %: 120 mins: Winter	88.231	88.118	0.346	0.268	3.5	8.605	0.000	0.000	2.1	5.402	72.731	OK
Bioretention (1)	FEH: 30 years: +35 %: 60 mins: Winter	88.310	87.875	0.335	0.025	4.6	5.388	0.000	0.000	3.1	3.454	80.867	OK
Bioretention (2)	FEH: 30 years: +35 %: 60 mins: Winter	88.204	88.103	0.369	0.303	3.5	4.092	0.000	0.000	2.1	3.444	75.638	OK
Bioretention (3)	FEH: 30 years: +35 %: 60 mins: Winter	88.170	87.840	0.353	0.040	7.0	5.824	0.000	0.000	5.8	7.732	74.371	OK
Porous Paving (11)	FEH: 30 years: +35 %: 15 mins: Winter	88.763	88.229	0.050	0.019	4.1	0.732	0.000	0.000	2.6	1.796	87.068	OK
Porous Paving (12)	FEH: 30 years: +35 %: 15 mins: Winter	88.457	88.195	0.024	0.017	3.1	0.354	0.000	0.000	2.3	1.346	91.633	OK
Porous Paving (13)	FEH: 30 years: +35 %: 15 mins: Winter	88.457	88.196	0.024	0.018	3.1	0.358	0.000	0.000	2.3	1.346	91.545	OK
Porous Paving (14)	FEH: 30 years: +35 %: 15 mins: Winter	88.424	88.194	0.022	0.016	2.5	0.275	0.000	0.000	2.0	1.132	92.208	OK
Porous Paving (15)	FEH: 30 years: +35 %: 15 mins: Winter	88.459	88.195	0.024	0.017	3.1	0.355	0.000	0.000	2.3	1.354	91.639	OK
Porous Paving (16)	FEH: 30 years: +35 %: 15 mins: Winter	88.437	88.169	0.022	0.012	1.7	0.129	0.000	0.000	1.4	0.748	94.403	OK

JD Sports Campus:	Date: 15/10/2025		
	Designed by: RM	Checked by: JH	Approved By: PV
Report Details: Type: Stormwater Controls Summary Storm Phase: Phase	Kennedy Redford: 20 Market Street Altrincham WA14 1PF		



Porous Paving (17)	FEH: 30 years: +35 %: 15 mins: Winter	88.437	88.168	0.022	0.011	1.7	0.124	0.000	0.000	1.4	0.749	94.624	OK
Porous Paving	FEH: 30 years: +35 %: 30 mins: Winter	88.264	88.121	0.085	0.038	16.3	6.215	0.000	0.000	11.2	13.743	71.193	OK
Porous Paving (1)	FEH: 30 years: +35 %: 30 mins: Winter	88.172	88.048	0.054	0.026	9.5	3.965	0.000	0.000	6.3	7.798	79.968	OK
Porous Paving (2)	FEH: 30 years: +35 %: 30 mins: Winter	88.111	87.994	0.054	0.033	9.5	4.056	0.000	0.000	6.2	7.775	79.519	OK
Porous Paving (3)	FEH: 30 years: +35 %: 30 mins: Winter	88.080	87.930	0.084	0.030	11.5	5.039	0.000	0.000	7.3	9.538	74.574	OK
Cellular Storage	FEH: 30 years: +35 %: 360 mins: Winter	87.466	87.466	1.086	1.086	42.6	288.920	0.000	0.000	15.0	144.112	9.769	OK

JD Sports Campus:	Date: 15/10/2025		
	Designed by: RM	Checked by: JH	Approved By: PV
Report Details: Type: Stormwater Controls Summary Storm Phase: Phase	Kennedy Redford: 20 Market Street Altrincham WA14 1PF		





FEH: 100 years: Increase Rainfall (%): +40: Critical Storm Per Item: Rank By:
Max. Avg. Depth

Stormwater Control	Storm Event	Max. US Level (m)	Max. DS Level (m)	Max. US Depth (m)	Max. DS Depth (m)	Max. Inflow (L/s)	Max. Residual Volume (m³)	Max. Flooded Volume (m³)	Total Lost Volume (m³)	Max. Outflow (L/s)	Total Discharge Volume (m³)	Percentage Available (%)	Status
Porous Paving (5)	FEH: 100 years: +40 %: 480 mins: Winter	88.115	88.115	0.051	0.065	0.8	1.187	0.000	0.000	0.7	8.044	81.411	OK
Porous Paving (6)	FEH: 100 years: +40 %: 480 mins: Winter	88.116	88.114	0.051	0.064	1.5	1.291	0.000	0.000	1.5	15.494	81.441	OK
Porous Paving (7)	FEH: 100 years: +40 %: 480 mins: Winter	88.116	88.115	0.051	0.065	1.5	1.295	0.000	0.000	1.5	15.773	81.394	OK
Porous Paving (8)	FEH: 100 years: +40 %: 480 mins: Winter	88.114	88.115	0.050	0.065	1.4	1.175	0.000	0.000	0.8	8.610	81.597	OK
Bioretention	FEH: 100 years: +40 %: 60 mins: Winter	88.251	88.139	0.366	0.289	7.6	9.958	0.000	0.000	3.6	6.215	68.441	OK
Bioretention (1)	FEH: 100 years: +40 %: 60 mins: Winter	88.314	87.883	0.339	0.033	6.1	6.002	0.000	0.000	5.5	5.782	78.688	OK
Bioretention (2)	FEH: 100 years: +40 %: 360 mins: Winter	88.276	88.275	0.441	0.475	1.8	12.138	0.000	0.000	2.1	16.127	27.729	OK
Bioretention (3)	FEH: 100 years: +40 %: 360 mins: Winter	88.340	88.340	0.523	0.540	4.2	25.994	3.376	0.000	5.8	36.541	-14.390	Flood
Porous Paving (11)	FEH: 100 years: +40 %: 15 mins: Winter	88.772	88.294	0.059	0.084	20.5	1.236	0.000	0.000	6.3	3.500	78.148	OK
Porous Paving (12)	FEH: 100 years: +40 %: 15 mins: Winter	88.461	88.198	0.028	0.020	4.0	0.417	0.000	0.000	3.2	1.774	90.159	OK
Porous Paving (13)	FEH: 100 years: +40 %: 15 mins: Winter	88.461	88.200	0.028	0.022	4.0	0.421	0.000	0.000	3.2	1.773	90.056	OK
Porous Paving (14)	FEH: 100 years: +40 %: 15 mins: Winter	88.427	88.197	0.026	0.019	3.3	0.321	0.000	0.000	2.8	1.483	90.911	OK
Porous Paving (15)	FEH: 100 years: +40 %: 15 mins: Winter	88.463	88.198	0.028	0.020	4.0	0.417	0.000	0.000	3.2	1.783	90.175	OK
Porous Paving (16)	FEH: 100 years: +40 %: 15 mins: Winter	88.440	88.171	0.025	0.014	2.2	0.149	0.000	0.000	1.9	0.976	93.539	OK

JD Sports Campus:	Date: 15/10/2025		
	Designed by: RM	Checked by: JH	Approved By: PV
Report Details: Type: Stormwater Controls Summary Storm Phase: Phase	Kennedy Redford: 20 Market Street Altrincham WA14 1PF		



Porous Paving (17)	FEH: 100 years: +40 %: 15 mins: Winter	88.440	88.169	0.026	0.012	2.2	0.143	0.000	0.000	1.9	0.976	93.786	OK
Porous Paving	FEH: 100 years: +40 %: 30 mins: Winter	88.294	88.128	0.115	0.045	21.6	7.821	0.000	0.000	15.1	18.521	63.751	OK
Porous Paving (1)	FEH: 100 years: +40 %: 30 mins: Winter	88.187	88.052	0.069	0.030	12.6	4.805	0.000	0.000	8.8	10.587	75.727	OK
Porous Paving (2)	FEH: 100 years: +40 %: 480 mins: Winter	88.116	88.115	0.059	0.154	5.5	6.783	0.000	0.000	2.1	26.654	65.751	OK
Porous Paving (3)	FEH: 100 years: +40 %: 480 mins: Winter	88.115	88.115	0.119	0.215	11.4	10.687	0.000	0.000	3.5	34.687	46.070	OK
Cellular Storage	FEH: 100 years: +40 %: 240 mins: Winter	88.136	88.136	1.756	1.756	77.2	319.822	0.000	0.000	17.3	104.411	0.118	OK